

NEW HAVEN CITY PLAN COMMISSION ADMINSTRATIVE SITE PLAN REVIEW

1513-03A1 301-305 GEORGE STREET AND 274 CROWN STREET. Administrative Site Plan Review for modifications to stormwater management system. (Owner: Robert Smith for Metro Star Property Management; Applicant/Agent: David Sacco for TPA Design Group)

Review Date: November 15, 2016

Submission received November 14, 2016:


- DATA Sheet and Narrative
- Check for \$100
- Revised drainage calculations, revised November 10, 2016.
- Sheet G-1.0: Grading, Drainage, and Utilities Plan. Revision date November 2, 2016.

The applicant proposes to change the quantity and arrangement of subsurface retention/infiltration units in order to reduce and relocate the system footprint to avoid any conflict with a proposed underground transformer vault proposed by United Illuminating.

ACTION

Plans noted above are approved.

Date: November 16, 2016
Noticed by City Plan Commission



Anne K.E. Hartjen PLA, ASLA
Senior Project Manager