Draft MS4 Stormwater Annual Report

2022

Available for public comments.

Please address all comments to:-

Giovanni Zinn
City Engineer
200 Orange Street, Room 503
New Haven CT 06510

by March 31st, 2023

MS4 General Permit City of New Haven 2022 Annual Report Existing MS4 Permittee Permit Number GSM 000030

[January 1, 2022 – December 31, 2022]

This report documents the City of New Haven's efforts to comply with the conditions of the MS4 General Permit to the maximum extent practicable (MEP) from January 1, 2021 to December 31, 2021.

Part I: Summary of Minimum Control Measure Activities

1. Public Education and Outreach (Section 6 (a)(1) / page 19)

ВМР	Status	Activities in current reporting period	Measurable goal	Department / Person Responsible	Due	Date completed or projected completion date	Additional details
1-1 Implement public education and outreach	Ongoing	- Signage at green infrastructure (GI) installations -West River Watershed Coalition river walks -Promotion of GI and sustainable land use practices in Climate and Sustainability Framework and in 2022 Sustainable CT certificationActive watershed groups: Mill River Watershed Association and West River Watershed Coalition.	Link to website, # signs installed, # of people reached, Link to Framework, # storm drain art installations.	Engineering	Ongoing	Continuing	Link to New Haven Climate and Sustainability Framework http://newhavenct.gov/gov/ depts/engineering/sustainability.htm storm drain art link https://lotsoffish.info/storm-drain-art West River Watershed Coalition https://www.westriverwatershed.org/ Mill River Watershed Coalition https://millriverofsouthcentralct.org/

1-2 Address	Ongoing	Research on effectiveness	# of litter	Engineering	Ongoing	Continuing
education/		of infrastructure to capture	trap	1 1		
outreach for pollutants of		litter in collaboration with Yale School of the	installations,			
concern*		Environment.				

1.2 Describe any Public Education and Outreach activities planned for the next year, if applicable.

- Continue support of watershed groups including the Mill River Watershed Association and the West River Watershed Coalition.
- Continue research partnership with non-profit and university on effectiveness of litter prevention methods.

1.3 Details of activities implemented to educate the community on stormwater

Program Element/Activity	Audience (and number of people reached)	Topic(s) covered	Pollutant of Concern addressed (if applicable)	Responsible dept. or partner org.
Maintain signage at over 55 GI installations.	Entire city with New Haven Independent article and signage.	- Impact of impervious cover - Purpose of GI and how it works		Engineering in partnership with Urban Resources Initiative and Save the Sound
Update of GI and sustainable land use practices in New Haven's 2022 Sustainable Connecticut Certification.	All publicly available on the Sustainable Connecticut website.	- Impact of impervious cover, fertilizers, pesticides - Purpose of GI		Engineering
Research project to install, monitor, and assess the effectiveness of three litter traps at the end of three stormwater outfalls discharging to Beaver Pond (tributary to West River)	Results of the research will be used to develop anti-litter outreach campaign	-litter - sources of pollutants		Engineering Dept in collaboration with Urban Resources Initiative, Yale School or Forestry and Environmental Studies

West River Watershed Coalition and the Mill River Watershed association lead walks and hikes along the banks of the West River and Mill River to educate and garner up interest in the restoration of these resources.	Dozens of events held every year	-Impact of impervious cover - West and Mill Rivers as community resources watershed restoration	West River Watershed Coalition and Mill River Watershed Association.
Mill River Watershed Association holds monthly meetings focused on watershed health	Monthly meetings with about 20-30 attendees	- Impact of impervious cover - Importance of local rivers - Watershed education and awareness	City Plan and Engineering
West River Watershed Coalition hosted workshops to review progress and prioritize actions from their 2015 watershed management plan	Four workshops with about 15-30 people in attendance at each	- Watershed education and awareness - Importance of local rivers - Watershed restoration - Water quality	West River Watershed Coalition, Engineering Dept

2. Public Involvement/Participation (Section 6(a)(2) / page 21)

2.1 BMP Summary

ВМР	Status	Activities in current reporting period	Measurable goal	Department / Person Responsible	Due	Date completed or projected completion date	Additional details
2-1 Continue availability of Final Stormwater Management Plan to the public	Ongoing	SWMP available on website (see below 2.3)	Link to plan	Engineering	Ongoing	Completed	Website:- http://www.newhavenct.gov/government/departments-divisions/engineering/stormwater
2-2 Comply with public notice requirements for Annual Reports	Ongoing	Annual Report available on website (see below 2.3)	Link to draft report	Engineering	2/18/2022	To be completed annually on Feb 15 th	Website:- http://www.newhavenct.gov/government/departments-divisions/engineering/stormwater

2.2 Describe any Public Involvement/Participation activities planned for the next year, if applicable.

None are planned at present by the City, but these activities are expected to occur. Many are instigated by the City's Environmental Advisory Council, or by the West River and Mill River Watershed associations

2.3 Public Involvement/Participation reporting metrics

Metrics	Implemented	Date	Posted
Availability of the Stormwater Management Plan to public	Υ	July 2017	A hard copy is kept for public review at the Engineering Department's reception desk, Hall of Records, 200 Orange Street, New Haven. Additionally, an electronic version is published on the City's web site at: http://www.newhavenct.gov/gov/depts/engineering/stormwater.htm
Availability of Annual Report announced to public	Υ	2/15/2023	A hard copy is kept for public review at the Engineering Department's reception desk, Hall of Records, 200 Orange Street, New Haven. Additionally, an electronic version is published on the City's web site at:- http://www.newhavenct.gov/government/departments-divisions/engineering/stormwater

3. Illicit Discharge Detection and Elimination (Section 6(a)(3) and Appendix B / page 22)

вмР	Status	Activities in current reporting period	Measurable goal	Department / Person Responsible	Due	Date completed or projected completion date	Additional details
3-1 Develop written IDDE program	Completed	IDDE protocol researched and written in early 2018	IDDE Protocol Document	Engineering	Jul 1, 2018	March 2, 2018	The document is considered to be a 'living document', in as far as it will be modified over time as new problems are encountered, and as experience is gained
3-2 Develop list and maps of all MS4 stormwater outfalls in priority areas	Completed	Minor updating when errors or omissions have been detected during field visits	(1) Excel spreadsheet listing all outfalls, locations and type of construction. (2) A photo log of all outfalls with condition data. (3) 1" to 80" plans showing all outfalls and listing their drainage basins.	Engineering	Jul 1, 2019	In stages between 2004 and 2009	The City's outfalls drain to the Quinnipiac, Mill River, West River, and New Haven Inner and Outer harbor. All are waters impaired by bacteria, nitrogen and phosphorus. A water testing program is underway to determine priorities. During 2019 the list was reviewed to remove outfalls in DOT property that are now covered by their MS4 Permit. This exercise is now about 90% complete, and to date has reduced the number of outfalls covered by the City's permit from 260 to 172.
3-3 Implement citizen reporting program	Completed	Monitoring of the "See Click- Fix" web site for citizen reports, and rectification	"See Click- Fix" website	All City Departments	Jul 1, 2017	Circa 2010	Citizen reports cover a large number of issues affecting stormwater run-off, from blocked or damaged catch basins through to illegal dumping. Appendix 1 of the 2018 Report includes a typical "See Click-Fix" posting

		of the problem					
3-4 Establish legal authority to prohibit illicit discharges	Completed	No enforcement actions have been taken during 2018	Title III Chapter26 Code of Ordinances	Engineering and Corporation Counsel	Jul 1, 2018	June 6, 2016	Can be viewed at - https://library.municode.com/ct/ new_haven/codes/code_of_ordinances?nodeId= TITIIICOGEOR_CH26STDI&showChanges
3-5 Develop record keeping system for IDDE tracking	Completed	Review of CCTV footage of storm drains to detect any illicit connections	70,000 linear feet of CCTV footage per year	Engineering	Jul 1, 2017	Not known	CCTV footage is kept on a hard drive with all pipe lengths uniquely numbered. This is backed up by drawings illustrating the pipe networks. For each outfall, a register is kept of any potential problem areas.
3-6 Address IDDE in areas with pollutants of concern	On-going		Prompt removal of illicit connection	Engineering	Not specified		Illicit connections into the storm system will be removed when found. To date, the CCTV inspections have found no illicit connections.
3-7 CCTV of storm lines to search for illicit connections	On-going	Approx 1,500 ft of storm line CCTVed in 2022	5,000 linear feet of CCTV footage in 2022	Engineering		Continuing	During 2022, CCTV work has been routine detection of defects and blockages. It has also been reviewed for illicit connections, but none were found.

3.2 Describe any IDDE activities planned for the next year, if applicable.

The CCTV program has been in operation for approximately five years. To date approximately 100,000 linear feet have been given a preliminary review, with no definitive illicit connections located. CCTV work exclusively for IDDE purposes will resume later in 2023.

3.3 List of citizen reports of suspected illicit discharges received during this reporting period.

Date of Report	Location / suspected source	Response taken
No reports during 2022		

3.4 Provide a record of illicit discharges occurring during the reporting period and SSOs occurring July 2012 through end of reporting period using the following table.

Location (Lat long/ street crossing /address and receiving water)	Date and duration of occurrence	Discharge to MS4 or surface water	Estimated volume discharged	Known or suspected cause / Responsible party	Corrective measures planned and completed (include dates)	Sampling data (if applicable)
SSO response and						
record keeping is undertaken by the						
Greater New Haven Water Pollution Authority						

3.5 Briefly describe the method used to track illicit discharge reports, responses to those reports, and who was responsible for tracking this information.

- 1. The tracking system for illicit sanitary connections is as described in section 3.1.5 above. To date no such connections have been detected.
- 2. Records of other potentially polluting events are kept on the "see Click Fix" web site.
- 3. Direct citizen reports sent to City Engineer. City Engineer responsible for enforcement action and City Engineer and Assistant City Engineer responsible for tracking this information.

3.6 Provide a summary of actions taken to address septic failures using the table below.

Location and nature of structure with failing septic systems	Actions taken to respond to and address the failures	Impacted waterbody or watershed, if known
There are no precise records, but as of 2020 it is believed there are only 10 to 20 septic systems left in the City. There were no reports of failures during 2022.		

3.7 IDDE reporting metrics

Metrics	
Estimated or actual number of MS4 outfalls	146 (Up from 130 in 2021). The change is primarily due to errors and omissions in the city's mapping.
Estimated or actual number of interconnections	See below
Outfall mapping complete	100%
Interconnection mapping complete	100%
System-wide mapping complete (detailed MS4 infrastructure)	100%
Outfall assessment and priority ranking	See below
Dry weather screening of all High and Low priority outfalls complete	See below
Catchment investigations complete	See below
Estimated percentage of MS4 catchment area investigated	Approximately 75% to 80% complete.

3.8 Briefly describe the IDDE training for employees involved in carrying out IDDE tasks including what type of training is provided and how often is it given (minimum once per year).

There is no formal training system in place at present as all IDDE work to date has been undertaken by registered professional engineers. The main reference document for this work is "Illicit Discharge Detection & Elimination" by the Center for Watershed Protection.

4. Construction Site Runoff Control (Section 6(a)(4) / page 25)

ВМР	Status	Activities in current reporting period	Measurable goal	Department / Person Responsible	Due	Date completed or projected completion date	Additional details
4-1 Implement, upgrade, and enforce land use regulations or other legal authority to meet requirements of MS4 general permit	Completed	See 4.2 below		City Plan	Jul 1, 2019	Sept 19, 2011	
4-2 Develop/Implement plan for interdepartmental coordination in site plan review and approval	On-going	See 4.2 below	32 Site plan review applications in 2021	City Plan Engineering Building Dept	Jul 1, 2017	Since 2004	
4-3 Review site plans for stormwater quality concerns	On-going	See 4.2 below	32 Site plan review applications in 2021	Engineering	Jul 1, 2017	Since 2004	
4-4 Conduct site inspections	On-going	See 4.2 below	Records, do not exclusively track BMP inspections, but 90 to 100 inspections is considered a good estimate	Building Dept Engineering	Jul 1, 2017	Since 2004	
4-5 Implement procedure to allow public comment on site development	On-going	See 4.2 below	Monthly City Plan Commission meetings	City Plan Commission	Jul 1, 2017	Since 2004	
4-6 Implement procedure to notify developers about DEEP construction stormwater permit	On-going	See 4.2 below	This is part of the Site plan application process	City Plan	Jul 1, 2017	Since 2004	

4.2 Describe any Construction Site Runoff Control activities planned for the next year, if applicable.

The City Plan Commission reviews all development plans prior to approval. There are monthly meetings at which commissioners review developments and approve them, or otherwise. These meetings are open to all, and members of the public can comment on any aspect of a development. Various city departments review the plans prior to City Plan Commission review, and there are bi-monthly co-ordination meetings between the departments involved. In the case of stormwater, input is from City Plan, the Engineering Department, the Building Department, and the Greater New Haven Water Pollution Control Authority. As required by Section 60 of the Zoning Code, the developer's engineer submits a Stormwater Management Plan addressing compliance with the City's ordinances, including Soil Erosion and Sediment Control plans. A typical report is included as Appendix 2 of the 2018 Annual Report. As part of the approval process, City Plan prepares a project specific report indicating any special requirements. A typical example which has stormwater related requirements is included as Appendix 3 of the 2018 Annual Report. A building permit is not issued until all the conditions of an approval are met. Site inspections by Building Department and Engineering Department staff during construction ensure SESC controls are in place, and that all work is in compliance with the approved design, including stormwater elements, prior to the issuance of a Certificate of Occupancy.

Sections 57, 58 and 60 of Article VI of the City's code of ordinances are the mechanism by which the requirements of the MS4 permit are met. They include low impact development requirements and the retention on site of one inch of rainfall. They can be viewed at the following web address:-

https://library.municode.com/ct/new haven/codes/zoning?nodeId=ZOOR ARTVIOTDI

5. Post-construction Stormwater Management (Section 6(a)(5) / page 27)

ВМР	Status	Activities in current reporting period	Measurable goal	Department / Person Responsible	Due	Date completed or projected completion date	Additional details
5-1 Establish and/or update legal authority and guidelines regarding LID and runoff reduction in site development planning	Completed	See 4.2 above	Section 60 of the Zoning Ordinance	City Plan	Jul 1, 2021	Sept 19, 2011	

5-2 Enforce LID/runoff reduction requirements for development and redevelopment projects	On-going	See 4.2 above	Approximately 24 stormwater management plans submitted for development projects during 2022	City Plan	Jul 1, 2019	On-going	
5-3 Identify retention and detention ponds in priority areas	Completed	None	None	Engineering	Jul 1, 2019		There are no known retention / detention structures under the City's jurisdiction
5-4 Implement long-term maintenance plan for stormwater basins and treatment structures	Not necessary at the present time			Engineering	Jul 1, 2019	On-going	There are no known structures of these types under the City's jurisdiction.
5-5 DCIA mapping	On-going State of the state of	The City has approx. 260 1"=40' planimetric and topographic maps, and until 2022 DCIA was computed from these in a substantially manual way. This was found to be very inefficient and time consuming. During 2022 new staff were appointed to the GIS department, and work on updating the city's GIS system, in conjunction with the use of Archydro computer software will be used for this task going forward. In addition, the City is currently using mapping resources provided by UCONN	Completion	Engineering	Jul 1, 2020		

	NEMO for DCIA mapping and for baseline DCIA calculations. See below for details.		
5-6 Address post-construction issues in areas with pollutants of concern		Not specified	

5.2 Describe any Post-Construction Stormwater Management activities planned for the next year, if applicable.

See Section 6.2 below.			

5.3 Post-Construction Stormwater Management reporting metrics

Metrics	
Baseline (2012) Directly Connected Impervious Area (DCIA)	3,155 acres
DCIA disconnected (redevelopment plus retrofits)	34.4 acres have been disconnected due to retrofits within the public right of way (i.e. bioswales). In addition, there have been DCIA disconnections on private property since 2011 when Section 60 of the Zoning Ordinance was adopted. As this was prior to the 2017 MS4 Permit records were not kept. It is intended that records will be researched, and the amount of work already done will be quantified.
Retrofits completed	200 ROW bioswales
DCIA disconnected	Over 34.4 acres
Estimated cost of retrofits	178 bioswales throughout downtown cost \$2.52M. Not known for the private development projects.
Detention or retention ponds identified	There are no known detention or retention ponds under the City's jurisdiction

5.4 Briefly describe the method to be used to determine baseline DCIA.

The 2012 imperviousness layer was downloaded from the CT ECO website. This layer was used to calculate the imperviousness within the combined sewer areas of New Haven so that it can be subtracted out from the total impervious acreage. After subtracting out State Roads and Combined Sewer impervious cover from New Haven's total impervious acreage (according to UCONN's MS4 map), the total impervious cover within MS4 areas in New Haven is 3,809.7 acres. This amounts to 38% impervious after adjusting the City's total acreage minus the combined sewer and state road acreage (10,015.9 acres). Using the methodology developed by EPA for Massachusetts, the City was conservatively assigned as 'Highly Connected' and the associated equation was used to convert the total imperviousness percentage to DCIA percentage. The DCIA percentage is 31.5% or 3,155 acres.

In the future, the City plans to delineate watersheds for each of its outfalls at which time the DCIA for each watershed will be calculated. The same methodology as above will be applied. There may be some difference in the baseline DCIA due to the assignment of connectivity levels on the watershed rather than city-wide scale. Many neighborhoods outside of the downtown area are likely to be assigned as 'Average' rather than 'Highly Connected.' The City is still in the process of compiling the impervious acreage that has been disconnected due to redevelopment. The City's ROW bioswale program has disconnected about 34.4 acres of the City's directed connected impervious area (see Section 6.5 below)

6. Pollution Prevention/Good Housekeeping (Section 6(a)(6) / page 31)

вмР	Status	Activities in current reporting period	Measurable goal	Department / Person Responsible	Due	Date completed or projected completion date	Additional details
6-1 Develop/implement formal employee training program	On-going		Annual training of Public Works and Parks Dept operatives	Public Works Parks Dept	Jul 1, 2017	Continuing	Training materials in the form of presentation slides are available
6-2 Implement MS4 property and operations maintenance	On-going	Pavement sweeping and trash removal from the Public Works Garage, the Refuse Vehicle Garage, and the transfer Station sites	Meeting target pollutant levels in the relevant DEEP general permit	Public Works	Jul 1, 2018	Continuing	Facilities covered by DEEP Industrial Discharge General permits GSI000800, GSI001690 and GSI002097
6-3 Implement coordination with interconnected MS4s	On-going (as required)	Discussions with staff from West Haven and North Haven on minor issues and the exchange of information	See 3.7 above	Engineering	Not specified	Continuing as required	
6-4 Develop/implement program to control other sources of pollutants to the MS4		None		Engineering	Not specified		There are no known sources of other pollutants to the MS4
6-5 Evaluate additional measures for discharges to impaired waters*		None		Engineering	Not specified		In previous years ABTECH pollutant absorbing sponges were installed at the Public Works Garage, and although found to be effective they were prohibitively expensive
6-6 Track projects that disconnect DCIA	On-going	The Site Plan review process as described in 4.2 above has been on-going, and data has been included in the development reports, an example of which is included in Appendix 3 to the 2018 Report	Spread sheet listing all developments since 2017 with DCIA reductions	Engineering	Jul 1, 2017	Work is in progress on 2017 thru 2022 developments to quantify the DCIA already achieved.	It is intended, dependent on staff availability, to track projects back to 2012.

6-7 Implement infrastructure repair/rehab program	On-going	Approximately \$400,000 spent on minor repair and maintenance of stormwater infrastructure, mostly on catch basins and piping	Keeping all infrastructure in a state of good repair	Engineering	Jul 1, 2021	Continuing	
6-8 Develop/implement plan to identify/prioritize retrofit projects	On-going	Continued water sampling and testing to determine the worst polluted watersheds that will need attention first.		Engineering	Jul 1, 2020	Continuing	
6-9 Implement retrofit projects to disconnect 2% of DCIA	Commenced	Developing methodology for tracking new/re-development disconnection, retrofitting streets in downtown with ROW bioswales	Acres of impervious area disconnected	Engineering	Jul 1, 2022	Continuing	Over the last five years 286 bioswales have been installed in the public ROW, 200 of those within MS4 areas
6-10 Develop/implement street sweeping program	On-going	All streets within the City are swept 4 or 5 times annually between April and November	Visually clear of trash, dust, and leaves at all times	Public Works	Jul 1, 2017	Continuing	
6-11 Develop/implement catch basin cleaning program	On-going	4,130 routine cleanings of catch basins, approximately 45 emergency cleanings when either blocked or non-functioning, and 2,290 linear feet of storm line jetting to remove blockages	Clean every catch basin once every two years	Engineering	Jul 1, 2020	Continuing	
6-12 Develop/implement snow management practices	On-going	Application of chloride liquid de-icer and sand/salt as required. No specific metrics available	Maintenance of safe movement of traffic	Public Works	Jul 1, 2018	Continuing	

6.2 Describe any Pollution Prevention/Good Housekeeping activities planned for the next year, if applicable.

- 1. Continued street sweeping 4 or 5 times during the year
- 2. Continued catch basin cleaning Approx 4,500
- 3. Spill response As required
- 4. Illicit dumping response As required
- 5. Litter removal in the downtown area and city parks As required
- 6. Continued maintenance of bioswales and GI within the public right of way, including trash and sediment removal.

6.3 Pollution Prevention/ Good Housekeeping reporting metrics

Metrics	
Employee training provided for key staff	Yearly refresher class to all Public Works and Parks Department employees
Street sweeping	
Curb miles swept	231 miles swept monthly
Volume (or mass) of material collected	Not recorded
Catch basin cleaning	
Total catch basins in priority areas	Approx 8,500
Total catch basins in MS4	Approx 8,500
Catch basins inspected	Approx 4,130
Catch basins cleaned	Approx 4,130
Volume (or mass) of material removed from all catch basins	Approx 75,000 Cu F
Volume removed from catch basins to impaired waters (if known)	Approx 79,000 Cu F
Snow management	
Type(s) of deicing material used	Salt
Total amount of each deicing material applied	Varies based on storm event
Type(s) of deicing equipment used	Truck mounted
Lane-miles treated	231 miles

Snow disposal location	No data available
Staff training provided on application methods & equipment	Yearly refresher course at start of snow season
Municipal turf management program actions (for permittee properties in basins with N/P impairments)	
Reduction in application of fertilizers (since start of permit)	None used
Reduction in turf area (since start of permit)	Nothing substantial
Lands with high potential to contribute bacteria (dog parks, parks with open water, & sites with failing septic systems)	The City has approximately 2,000 acres of parkland, which have significant populations of birds and wildlife
Cost of mitigation actions/retrofits	None

6.4 Catch basin cleaning program

Provide any updates or modifications to your catch basin cleaning program

No changes. Expect to clean 4,500 in 2023

6.5 Retrofit program

Briefly describe the Retrofit Program identification and prioritization process, the projects selected for implementation, the rationale for the selection of those projects and the total DCIA to be disconnected upon completion of each project. [Provide information if available in 2018 report. Section to be completed for the 2019 Annual Report.]

Currently, in addition to the disconnection taking place as part of new and major re-development projects, the City is also retrofitting streets with right-of-way (ROW) bioswales. 286 bioswales have been installed thus far with 200 of these constructed within the MS4 watershed. The City will continue to incorporate green infrastructure into all its projects as applicable. Each bioswale has a catchment area of about 7,500 square feet (100:1 ratio of catchment area to bioswale footprint area). With 200 installations complete, the total disconnected impervious area from these installations is 34.4 acres, over 1% of the City's estimated DCIA.

Describe plans for continuing the Retrofit program and how to achieve a goal of 1% DCIA disconnection in future years. [Provide information if available in 2018 report. Section to be completed for the 2019 Annual Report.]

It is anticipated that the retrofit program will consist of two elements. One will be the continued installation of bioswales and incorporation of green infrastructure into the City's ROW projects. The other will be the retention of the first inch of rainfall on new and major re-developments, many of which are currently under construction, with more at the planning stage.

Describe plans for continuing the Retrofit program beyond this permit term with the goal to disconnect 1% DCIA annually over the next 5 years. [Provide information if available in 2018 report. Section to be completed for the 2019 Annual Report.]

As described in the previous section.

Part II: Impaired waters investigation and monitoring [This section required beginning with 2018 Annual Report]

1.	Impaired	waters	investigation	and	monitoring program	
----	-----------------	--------	---------------	-----	--------------------	--

1.1 Indicate which stormwater pollutan on the MS4 map viewer: http://s.ucor			cipality or institution. This data is availa	ole
Nitrogen/ Phosphorus	Bacteria 🗌	Mercury 🗌	Other Pollutant of Concern	

1.2 Describe program statu

Discuss 1) the status of monitoring work completed, 2) a summary of the results and any notable findings, and 3) any changes to the Stormwater Management Plan based on monitoring results.

The City has monitored water quality per the 2004 permit since its inception, and has always had bacteria, nitrogen and phosphorus levels above target levels, sometimes significantly so. The City was audited by the EPA during 2014 and 2016, at which times they undertook PPCP testing at the outfalls monitored by the City. These indicated that sewage was entering the storm system. The EPA test results were submitted to DEEP with the 2017 annual report. City staff have always believed that the high levels of bacteria are due to wildlife, which has probably contributed to the high levels of nitrogen also. In consequence the City undertook PPCP sampling of gutter flows in to catch basins. Several of the parameters in the PPCP spectrum had similar levels to those previously found at outfalls, reinforcing the City's opinion that the problems at the outfalls were due to contamination by animal excrement rather than sanitary sewer cross connections. The City has had an extensive sewer separation program in place for the last twenty years, and so far the CCTV review has found no illicit connections. No doubt some will be found in due course as the CCTV program proceeds.

The water testing undertaken during 2020 consisted monitoring at both the catch basins and outfalls, all samples on a network being collected within an hour of each other, so the test results would be a reasonably good comparison of what is going into the system with what is coming out. A review of the results available so far indicates that the stormwater entering at the catch basins is as polluted as that leaving the outfalls. Using the term "outfall" here is not fully correct as they are generally submerged. The sampling is at a close by upstream manhole.

Testing results since 2018 are included in Section 2.1 below, and also in Appendix 1, which also includes inflow data at catch basins. Going forward the City will sample at all outfalls and typical catch basins on selected pipe networks. All sampling is "Wet Weather", and the vast majority of tests are undertaken at a laboratory. The sampling and testing at catch basins can be looked on as the "follow up Investigation" of the situation at the outfall. Work will progress in the ranking order as indicated in Part iii Table 1 below, as far as is possible. Delineation of outfall catchments, the calculation of impervious areas, and the estimation of DCIA will proceed in the same order.

The following parameters have been and will be tested at all outfalls and selected catch basins :-

- 1. E-Coli (Col/100ml) *
- 2. Total coliform
- 3. Fecal coliform
- 4. Enterococci
- 5. Ammonia (mg/l) *
- 6. Chlorine
- 7. Conductivity (umos) *
- 8. Salinity
- 9. Surfactants
- 10. pH (SU) *
- 11. Hardness (mg/l) *
- 12. Oil and grease (mg/l) *
- 13. Chemical oxygen demand (mg/l) *
- 14. Turbidity (NTU) *
- 15. Total suspended solids (mg/l) *
- 16. Total phosphorus (mg/l) *
- 17. Total Kjeldahl Nitrogen (mg/l) *
- 18. Nitrate plus nitrite Nitrogen (mg/l) *
- 19. Temperature of sample *
- pH (SU) of uncontaminated rainfall *
- 21. Boron (mg/l)

The items marked * are the same parameters tested under the MS4 permit in place between 2004 and 2017. They are continuing to be monitored as they give a general indication as to how dirty the storm discharges are, and it is hoped a database built up over many years will indicate general improvements.

Starting mid-2018 all bacteria samples were split to be tested at two separate and independent laboratories as a check on their accuracy. This practice has been continued during 2021.

2. Screening data for outfalls to impaired waterbodies (Section 6(i)(1) / page 41)

2.1 Screening data

Complete the table below for any outfalls screened during the reporting period. Each Annual Report will add on to the previous year's screening data showing a cumulative list of outfall screening data.

Outfall ID	Sample date	Parameter (Nitrogen, Phosphorus, Bacteria, or Other pollutant of concern)	Results	Name of Laboratory (if used)	Follow-up required?
O-180 (5200-00)	6/21/18	Bacteria	E. coli 616 MPN/100mls Enterococci >24,200	Phoenix Phoenix	Yes
			MPN/100mls Fecal Coliform 605 MPN/100mls	Phoenix	Yes
			Total Coliform >24,200 MPN/100mls	Phoenix	Yes
		Nitrogen Phosphorus	Total N 3.08 mg/l Total P 0.123 mg/l	Phoenix Phoenix	Yes
O-119 (5305-00)	6/28/18	Bacteria	E.Coli 3,450 MPN/100mls	Phoenix	Yes
(22222)			Enterococci 12,000 MPN/100mls	Phoenix	Yes
			Fecal Coliform 4,110 MPN/100mls	Phoenix	Yes
			Total Coliform >242,000	Phoenix	Yes

		Phosphorus	Total P 0.076 mg/l	Phoenix	No
		Nitrogen	Total N 0.66 mg/l	Phoenix	No
			Total Coliform 17,300 MPN/100mls 17,250 MPN/100mls	Phoenix ECL	Yes
			Fecal Coliform 383 MPN/100mls 300 MPN/100mls	Phoenix ECL	Yes
			Enterococci 602 MPN/100mls 310 MPN/100mls	Phoenix ECL	Yes
O-11 11/13/18 (5305-00)	11/13/18	Bacteria	E Coli 609 MPN/100mls 200 MPN/100mls	Phoenix ECL	Yes
		Nitrogen Phosphorus	Total N 3.48 mg/l Total P 0.545 mg/l	Phoenix Phoenix	Yes
			MPN/100mls		

0-7	11/13/18	Bacteria	E Coli			
(5305-00)			>24,200	Phoenix	Yes	
			MPN/100mls			
			241,960	ECL	Yes	
			MPN/100mls			
			Enterococci			
			>24,200	Phoenix	Yes	
			MPN/100mls			
			>241,960	ECL	Yes	
			MPN/100mls			
			2 2001113			
			Fecal Coliform			
			>24,200	Phoenix	Yes	
			MPN/100mls	FIIOEIIIX	163	
			48,840 MPN/100mls	ECL	Yes	
			48,840 WIFIN/ 100IIIIS	ECL	163	
			Total Coliform			
				Observing	Voc	
			>24,200	Phoenix	Yes	
		· ·	MPN/100mls			
			>241,960	ECL	Yes	
			MPN/100mls			
		Nitrogen	Total N 14.69 mg/l			
				Phoenix	Yes	
		Phosphorus	Total P 1.34 mg/l			
				Phoenix	Yes	
0-10	12/28/18	Bacteria	E Coli			

(5305-00)			>24,200	Phoenix	Yes
			MPN/100mls >241,960 MPN/100mls	ECL	Yes
			Enterococci >24,200 MPN/100mls	Phoenix	Yes
			>241,960 MPN/100mls	ECL	Yes
			Fecal Coliform >24,200 MPN/100mls	Phoenix	Yes
			>241,960 MPN/100mls	ECL	Yes
			Total Coliform >24,200 MPN/100mls >241,960	Phoenix ECL	Yes
			MPN/100mls		
		Nitrogen	Total N 16.67 mg/l	Phoenix	Yes
		Phosphorus	Total P 1.76 mg/l	Phoenix	Yes
0-12	11/13/18	Bacteria	E Coli		
(5305-00)	11,13,13	Sections	5,480 MPN/100mls 5,040 MPN/100mls	Phoenix ECL	Yes Yes
			Enterococci 5,170 MPN/100mls 6,770 MPN/100mls	Phoenix ECL	Yes Yes
			Fecal Coliform 1,860 MPN/100mls 1,560 MPN/100mls	Phoenix ECL	Yes Yes
			Total Coliform >24,200 MPN/100mls 198,630	Phoenix	Yes
			MPN/100mls	ECL	Yes
		Nitrogen	Total N 0.44 mg/l Total P 0.229 mg/l	Phoenix	No
		Phosphorus	Total P 0.229 Ing/I	Phoenix	No
O13 (5305-00)	12/28/18	Bacteria	E Coli >24,200 MPN/100mls	Phoenix	Yes
			>241,960	ECL	Yes

			MPN/100mls		
			Enterococci		
			>24,200	Phoenix	Yes
			MPN/100mls		
			61,310	ECL	Yes
			MPN/100mls		
			Fecal Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls		
			155,310	ECL	Yes
			MPN/100mls		
			Total Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls		
			>241,960	ECL	Yes
			MPN/100mls		
		Nitrogen	Total N 17.49mg/l	Phoenix	Yes
		Phosphorus	Total P 2.02mg/l	Phoenix	Yes
)-41	12/28/18	Bacteria	E Coli		
5305-00)			>24,200	Phoenix	Yes
•			MPN/100mls		
			>241,960	ECL	Yes
			MPN/100mls		
			Enterococci		
			>24,200	Phoenix	Yes
			MPN/100mls	,	
			92,080	ECL	Yes
			MPN/100mls		
			MPN/100mls Fecal Coliform		
			MPN/100mls	Phoenix	Yes
			MPN/100mls Fecal Coliform		Yes
			MPN/100mls Fecal Coliform >24,200		Yes
			MPN/100mls Fecal Coliform >24,200 MPN/100mls	Phoenix	
			MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960 MPN/100mls	Phoenix	
			MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960 MPN/100mls Total Coliform	Phoenix	Yes
			MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960 MPN/100mls Total Coliform >24,200	Phoenix	
			MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960 MPN/100mls Total Coliform >24,200 MPN/100mls	Phoenix ECL Phoenix	Yes
			MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960 MPN/100mls Total Coliform >24,200 MPN/100mls >241,960	Phoenix	Yes
			MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960 MPN/100mls Total Coliform >24,200 MPN/100mls	Phoenix ECL Phoenix	Yes
			MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960 MPN/100mls Total Coliform >24,200 MPN/100mls >241,960 MPN/100mls	Phoenix ECL Phoenix ECL	Yes Yes
		Nitrogen	MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960 MPN/100mls Total Coliform >24,200 MPN/100mls >241,960	Phoenix ECL Phoenix	Yes
			MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960 MPN/100mls Total Coliform >24,200 MPN/100mls >241,960 MPN/100mls Total N 11.49 mg/l	Phoenix ECL Phoenix ECL Phoenix	Yes Yes Yes
		Nitrogen Phosphorus	MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960 MPN/100mls Total Coliform >24,200 MPN/100mls >241,960 MPN/100mls	Phoenix ECL Phoenix ECL	Yes Yes
0.45	12/21/19	Phosphorus	MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960 MPN/100mls Total Coliform >24,200 MPN/100mls >241,960 MPN/100mls Total N 11.49 mg/l Total P 1.33 mg/l	Phoenix ECL Phoenix ECL Phoenix	Yes Yes Yes
O-46 (5305-00)	12/21/18		MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960 MPN/100mls Total Coliform >24,200 MPN/100mls >241,960 MPN/100mls Total N 11.49 mg/l	Phoenix ECL Phoenix ECL Phoenix	Yes Yes Yes

			Catanagasi		
			Enterococci		
			2,280 MPN/100mls	Phoenix	Yes
			1,990MPN/100mls	ECL	Yes
			Fecal Coliform		
			197 MPN/100mls	Phoenix	Yes
			200 MPN/100mls	ECL	Yes
			T-t-I California		
			Total Coliform		
			9,800 MPN/100mls	Phoenix	Yes
			8,420 MPN/100mls	ECL	Yes
			T . 101 0 40 //	Ob	
		Nitrogen	Total N 0.42 mg/l	Phoenix	No
		Phosphorus	Total P 0.13 mg/l	Phoenix	No
		Thosphorus	10tar 1 0.15 mg/	1 Hoelinx	110
)-47	12/21/18	Bacteria	E Coli		
5305-00)			9,140 MPN/100mls	Phoenix	Yes
			3,360 MPN/100mls	ECL	Yes
			3,300 WENT TOURS	LCL	163
			Enterococci		
			3,870 MPN/100mls	Phoenix	Yes
				ECL	
			1,580 MPN/100mls	ECL	Yes
			Fecal Coliform		
			5,170 MPN/100mls	Phoenix	Yes
			1,610 MPN/100mls	ECL	Yes
			Total Coliform		
			10,100 MPN/100mls	Phoenix	Yes
			13,540 MPN/100mls	ECL	Yes
		Nitrogen	Total N 0.72 mg/l	Phoenix	No
		Microgen	Total IV 0.72 mg/	THOCHIA	
		Phosphorus	Total P 0.161 mg/l	Phoenix	No
D-57	12/28/18	Bacteria	E Coli		
	12/20/10	Ducteria		Dhaoniu	Voc
5305-00)			>24,200	Phoenix	Yes
			MPN/100mls		
			>241,960	ECL	Yes
			MPN/100mls	100	
			IVIPIN/ TOUTIIS		
			Enterococci		
			>24,200	Phoenix	Yes
				HOCHIA	103
			MPN/100mls		
				ECL	Vos
			>241,960	LCL	Yes
				ECL	res
			>241,960 MPN/100mls	LCL	Tes
			MPN/100mls	LCL	res
			MPN/100mls Fecal Coliform		
			MPN/100mls Fecal Coliform		Yes
			MPN/100mls Fecal Coliform >24,200	Phoenix	
			MPN/100mls Fecal Coliform >24,200 MPN/100mls	Phoenix	Yes
			MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960		
			MPN/100mls Fecal Coliform >24,200 MPN/100mls	Phoenix	Yes
			MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960	Phoenix	Yes
			MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960 MPN/100mls	Phoenix	Yes
			MPN/100mls Fecal Coliform >24,200 MPN/100mls >241,960	Phoenix	Yes

			MPN/100mls >241,960 MPN/100mls	ECL -	Yes
		Nitrogen	Total N 32.24 mg/l	Phoenix	Yes
		Phosphorus	Total P 4.09 mg/l	Phoenix	Yes
O-58 (5305-00)	12/28/18	Bacteria	E Coli >24,200 MPN/100mls	Phoenix	Yes
			>241,960 MPN/100mls	ECL	Yes
			Enterococci		
			>24,200 MPN/100mls	Phoenix	Yes
			81,640 MPN/100mls	ECL	Yes
			Fecal Coliform		
			>24,200 MPN/100mls	Phoenix	Yes
			>241,960 MPN/100mls	ECL	Yes
			Total Coliform		
			>24,200 MPN/100mls	Phoenix	Yes
			>241,960 MPN/100mls	ECL	Yes
		Nitrogen	Total N 26.01 mg/l	Phoenix	Yes
		Phosphorus	Total P 2.96 mg/l	Phoenix	Yes

D-66	11/13/18	Bacteria	E Coli			
5305-00)			3,080 MPN/100mls	Phoenix	Yes	
			2,350 MPN/100mls	ECL	Yes	
		- 8	Enterococci			
			2,190 MPN/100mls	Phoenix	Yes	
			1,350 MPN/100mls	ECL	Yes	
			Fecal Coliform			
			1,480 MPN/100mls	Phoenix	Yes	
			1,610 MPN/100mls	ECL	Yes	
			Total Coliform			
			>24,200	Phoenix	Yes	
			MPN/100mls			
			61,310	ECL	Yes	
			MPN/100mls			
		Nitrogen	Total N 0.49 mg/l	Phoenix	No	

		Phosphorus	Total P 0.182 mg/l	Phoenix	No	
O-68 (5305-00)	12/28/18	Bacteria	E Coli 30 MPN/100mls 100 MPN/100mls	Phoenix ECL	No No	
			Enterococci 249 MPN/100mls 8,600 MPN/100mls	Phoenix ECL	No Yes	
			Fecal Coliform 20 MPN/100mls 100 MPN/100mls	Phoenix ECL	No No	
			Total Coliform 13,000	Phoenix	Yes	
			MPN/100mls 5,810 MPN/100mls	ECL	Yes	
		Nitrogen	Total N 0.95 mg/l	Phoenix	No	
		Phosphorus	Total P 0.07 mg/l	Phoenix	No	
O-81 (5305-00)	6/18/19	Bacteria	E Coli 2,060 MPN/100mls	Phoenix	Yes	
			Enterococci 9,210 MPN/100mls	Phoenix	Yes	
			Fecal Coliform 934 MPN/100mls	Phoenix	Yes	
			Total Coliform >24,200 MPN/100mls	Phoenix	Yes	
		Nitrogen	Total N 0.76 mg/l	Phoenix	No	
		Phosphorus	Total P 0.072 mg/l	Phoenix	No	
0-87	12/28/18	Bacteria	E Coli			
(5305-00)			30 MPN/100mls 100 MPN/100mls	Phoenix ECL	No No	
			Enterococci 249 MPN/100mls 8,600 MPN/100mls	Phoenix ECL	No Yes	
			Fecal Coliform 20 MPN/100mls	Phoenix	No	
			100 MPN/100mls	ECL	No	
			Total Coliform 13,000 MPN/100mls	Phoenix	Yes	

			5,810 MPN/100mls	ECL	Yes
		Nitrogen	Total N 24.37 mg/l	Phoenix	No
		Phosphorus	Total P 0.07 mg/l	Phoenix	No
-88 (305-00)	12/28/18	Bacteria	E Coli 591 MPN/100mls	Phoenix	Yes
1303-00)			520 MPN/100mls	ECL	Yes
			Enterococci 471 MPN/100mls	Phoenix	Yes
			1,100 MPN/100mls	ECL	Yes
			Fecal Coliform 637 MPN/100mls	Phoenix	Yes
			200 MPN/100mls	ECL	Yes
			Total Coliform >24,200	Phoenix	Yes
			MPN/100mls		
			30,760 MPN/100mls	ECL	Yes
		Nitrogen	Total N 0.826 mg/l	Phoenix	Yes
		Phosphorus	Total P 0.105 mg/l	Phoenix	No
)-89	12/21/18	Bacteria	E Coli		
5305-00)	12/21/10	buccena	7,700 MPN/100mls 9,590 MPN/100mls	Phoenix	Yes
				ECL	Yes
			Enterococci 5,480 MPN/100mls	Phoenix	Yes
			5,540 MPN/100mls	ECL	Yes
			Fecal Coliform 2,610 MPN/100mls	Phoenix	Yes
			2,980 MPN/100mls	ECL	Yes
			Total Coliform >24,200	Phoenix	Yes
			MPN/100mls		
			46,110 MPN/100mls	ECL	Yes
		Nitrogen	Total N 0.72 mg/l	Phoenix	No
		Phosphorus	Total P 0.133 mg/l	Phoenix	No

E Coli

>24,200 MPN/100mls

Phoenix

Yes

Bacteria

0-121

(5302-00)

12/21/18

			Enterococci >24,200 MPN/100mls	Phoenix	Yes
			Fecal Coliform >24,200 MPN/100mls	Phoenix	Yes
			Total Coliform >24,200 MPN/100mls	Phoenix	Yes
		Nitrogen	Total N 26.94 mg/l	Phoenix	Yes
		Phosphorus	Total P 4.0 mg/l	Phoenix	Yes
O-122 (5302-00)	4/26/19	Bacteria	E Coli 7,270 MPN/100mls	Phoenix	Yes
			Enterococci 3,080 MPN/100mls	Phoenix	Yes
			Fecal Coliform 4,880 MPN/100mls	Phoenix	Yes
			Total Coliform		
			>24,200 MPN/100mls	Phoenix	Yes
		Nitrogen	Total N 3.77 mg/l	Phoenix	Yes
		Phosphorus	Total P 0.40 mg/l	Phoenix	Yes
O-124 (5302-00)	4/26/19	Bacteria	E Coli >24,200 MPN/100mls	Phoenix	Yes
			Enterococci 4,610 MPN/100mls	Phoenix	Yes
			Fecal Coliform >24,200 MPN/100mls	Phoenix	Yes
			Total Coliform >24,200 MPN/100mls	Phoenix	Yes
		Nitrogen	Total N 78.95 mg/l	Phoenix	Yes
		Phosphorus	Total P 8.51 mg/l	Phoenix	Yes
O-124X (5302-00)	4/26/19	Bacteria	E Coli 216 MPN/100mls	Phoenix	No

			Enterococci 134 MPN/100mls	Phoenix	No
			Fecal Coliform 395 MPN/100mls	Phoenix	Yes
			Total Coliform 19,900 MPN/100mls	Phoenix	Yes
		Nitrogen	Total N 2.623 mg/l	Phoenix	Yes
		Phosphorus	Total P 0.196 mg/l	Phoenix	no
O-125 (5302-00)	4/26/19	Bacteria	E Coli 10 MPN/100mls	Phoenix	No
			Enterococci 61 MPN/100mls	Phoenix	no
ı			Fecal Coliform 10 MPN/100mls	Phoenix	Yes
			Total Coliform 934 MPN/100mls	Phoenix	Yes
		Nitrogen	Total N 1.13 mg/l	Phoenix	Yes
		Phosphorus	Total P 0.067 mg/l	Phoenix	Yes
O-126 (5302-00)	4/26/19		E Coli >24,200 MPN/100mls	Phoenix	Yes
			Enterococci >24,200 MPN/100mls	Phoenix	Yes
			Fecal Coliform >24,200 MPN/100mls	Phoenix	Yes
			Total Coliform >24,200 MPN/100mls	Phoenix	Yes
			Total N 26.94 mg/l	Phoenix	Yes
			Total P 4.00 mg/l	Phoenix	Yes
O-126 (5302-00)	12/9/19	Bacteria	E Coli 2,600 MPN/100mls 2,750 MPN/100mls	Phoenix ECL	Yes Yes
			Enterococci >24,200 MPN/100mls	Phoenix	Yes

			111 000	F.C.I	Yes
			111,990 MPN/100mls	ECL	res
			1011 107 20011113		
			Fecal Coliform		
			1,080 MPN/100mls	Phoenix	Yes
			2,130 MPN/100mls	ECL	Yes
			Total Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls		
			>241,960	ECL	Yes
			MPN/100mls		
		Nitrogen	Total N 4.014 mg/l	Phoenix	Yes
		Mitrogen	10(a) N 4.014 mg/1	FIIOEIIIX	163
		Phosphorus	Total P 0.812 mg/l	Phoenix	Yes
0-127	4/26/19	Bacteria	E Coli		
- 12/	., 20, 23	5555.10	703 MPN/100mls	Phoenix	Yes
			Enterococci	Dhasair	Vac
			1,170 MPN/100mls	Phoenix	Yes
			Fecal Coliform		
			24,200 MPN/100mls	Phoenix	No
			Total Coliform		W
			>24,200 MPN/100mls	Phoenix	Yes
			WIFIN/ TOUTHS		
		Nitrogen	Total N 2.445 mg/l	Phoenix	No
		Phosphorus	Total P 0.114 mg/l	Phoenix	No
0-128	4/26/19	Bacteria	E Coli		
(5302-00)			218 MPN/100mls	Phoenix	No
			Enterococci 1070 MPN/100mls	Phoenix	Yes
			1070 1417 14/ 10011113	THOCHIA	103
			Fecal Coliform		
			98 MPN/100mls	Phoenix	No
			T to location		
			Total Coliform >24,200	Phoenix	Yes
			MPN/100mls	HOEHIX	1.0
		Nitrogen	Total N 0.971 mg/l	Phoenix	No
		Phoenhorus	Total D 0 249 m=/1	Phoenix	No
	W. 1	Phosphorus	Total P 0.248 mg/l	FIIOEIIIX	INO
O-128	12/9/19	Bacteria	E Coli		
(5302-00)	-, -,		384 MPN/100mls	Phoenix	No
			410 MPN/100mls	ECL	No
			5.4		
			Enterococci		

			857 MPN/100mls 1,450 MPN/100mls	Phoenix ECL	Yes Yes
			Fecal Coliform		
			189 MPN/100mls	Phoenix	Yes
			520 MPN/100mls	ECL	Yes
			Total Coliform		
			>24,200 MPN/100mls	Phoenix	Yes
			21,870 MPN/100mls	ECL	Yes
			Total N 1.30 mg/l	Phoenix	No
		Nitrogen	Total P 0.174 mg/l	Phoenix	No
		Phosphorus		· · · · · · · · · · · · · · · · · · ·	
O-129 (5302-00)	6/18/19	Bacteria	E Coli 537 MPN/100mls	Phoenix	Yes
			Enterococci		1933
			988 MPN/100mls	Phoenix	Yes
			Fecal Coliform 437 MPN/100mls	Phoenix	Yes
				Phoenix	res
			Total Coliform 24,200 MPN/100mls	Phoenix	Yes
		Nitrogen	Total N 0.44 mg/l	Phoenix	Yes
		Phosphorus	Total P 0.047 mg/l	Phoenix	No
O-129 (5302-00)	12/9/19	Bacteria	E Coli 327 MPN/100mls	Phoenix	No
(3302-00)			100 MPN/100mls	ECL	No
			Enterococci		
			857 MPN/100mls	Phoenix	Yes
			1,090 MPN/100mls	ECL	Yes
			Fecal Coliform 189 MPN/100mls	Phoenix	Yes
			300 MPN/100mls	ECL	No
			Total Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls		
			>241,960 MPN/100mls	ECL	Yes
		Nitrogen			No.
		Phosphorus	Total N 2.136 mg/l	Phoenix	No
			Total P 0.265 mg/l	Phoenix	No
0-132	12/21/18	Bacteria	E Coli		

12,000 MPN/100mls						
Enterococci	(5302-00)					
2,190 MPN/100mls				7,490 MPN/100mls	ECL	Yes
Fecal Coliform 1,260 MPN/100mls ECL Yes						
Fecal Coliform 1,260 MPN/100mls 1,100 MPN/100						
1,260 MPN/100mls				630 MPN/100mls	ECL	Yes
1,100 MPN/100mls				Fecal Coliform		
Total Coliform						
19,900 MPN/100mls ECL Yes				1,100 MPN/100mls	ECL	Yes
18,600 MPN/100mls ECL Yes				Total Coliform		
Nitrogen						
Phosphorus				18,600 MPN/100mls	ECL	Yes
Factor F			Nitrogen	Total N 0.85 mg/l	Phoenix	No
171 MPN/100mls			Phosphorus	Total P 0.061 mg/l	Phoenix	No
171 MPN/100mls	0-133	6/18/19	Bacteria	E Coli	(4)	
Enterococci S54 MPN/100mls 1,630 MPN/100mls 1,630 MPN/100mls ECL Yes	(5320-00)					
S54 MPN/100mls				100 MPN/100mls	ECL	No
1,630 MPN/100mls						
Fecal Coliform 158 MPN/100mls Phoenix No 100 MPN/100mls ECL No No Total Coliform >24,200 Phoenix Yes MPN/100mls ECL Yes No MPN/100mls ECL Yes No MPN/100mls ECL Yes No MPN/100mls Phoenix Yes Fecal Coliform 3,650 MPN/100mls Phoenix Yes Total Coliform Yes Total Colif						
158 MPN/100mls				1,630 MPN/100mls	ECL	Yes
100 MPN/100mls ECL				Fecal Coliform		
Total Coliform						
				100 MPN/100mls	ECL	No
MPN/100mls				Total Coliform		
77,010 MPN/100mls ECL Yes Nitrogen Total N 1.19 mg/l Phoenix No Phosphorus Total P 0.135 mg/l Phoenix No Phosphorus E Coli 3,260 MPN/100mls Phoenix No Enterococci 8,660 MPN/100mls Phoenix Yes Fecal Coliform 3,650 MPN/100mls Phoenix Yes Total Coliform >24,200 Phoenix Yes					Phoenix	Yes
Nitrogen Phosphorus Total N 1.19 mg/l Phoenix No Total P 0.135 mg/l Phoenix No Bacteria E Coli 3,260 MPN/100mls Phoenix No Enterococci 8,660 MPN/100mls Phoenix Yes Fecal Coliform 3,650 MPN/100mls Phoenix Yes Total Coliform >24,200 Phoenix Yes					FCI	Voc
Phosphorus Total P 0.135 mg/l Phoenix No				77,010 WPW/100MIS	ECL	163
D-134 6/18/19 Bacteria E Coli 3,260 MPN/100mls Phoenix No			Nitrogen	Total N 1.19 mg/l	Phoenix	No
3,260 MPN/100mls Phoenix No Enterococci 8,660 MPN/100mls Phoenix Yes Fecal Coliform 3,650 MPN/100mls Phoenix Yes Total Coliform >24,200 Phoenix Yes			Phosphorus	Total P 0.135 mg/l	Phoenix	No
3,260 MPN/100mls Phoenix No Enterococci 8,660 MPN/100mls Phoenix Yes Fecal Coliform 3,650 MPN/100mls Phoenix Yes Total Coliform >24,200 Phoenix Yes		- 100 to 0		F.O. II.		
Enterococci 8,660 MPN/100mls Phoenix Yes Fecal Coliform 3,650 MPN/100mls Phoenix Yes Total Coliform >24,200 Phoenix Yes		6/18/19	Bacteria		Phoenix	No
8,660 MPN/100mls Phoenix Yes Fecal Coliform 3,650 MPN/100mls Phoenix Yes Total Coliform >24,200 Phoenix Yes	(3302-00)					*
Fecal Coliform 3,650 MPN/100mls Phoenix Yes Total Coliform >24,200 Phoenix Yes						V
3,650 MPN/100mls Phoenix Yes Total Coliform >24,200 Phoenix Yes				8,660 MPN/100mis	Pnoenix	Yes
Total Coliform >24,200 Phoenix Yes						
>24,200 Phoenix Yes				3,650 MPN/100mls	Phoenix	Yes
				Total Coliform		
MPN/100mls					Phoenix	Yes
				MPN/100mls		
Nitrogen Total N 1.189 mg/l Phoenix No			Nitrogen	Total N 1.189 mg/l	Phoenix	No
Phosphorus Total P 0.376 mg/l Phoenix Yes			Phosphorus	Total P 0.376 mg/i	Phoenix	Yes

0.130	12/21/10	Dostario	E Coli		
0-138	12/21/18	Bacteria		Dhaaain	Al-
(5302-00)			211 MPN/100mls	Phoenix	No
			Enterococci		1883
			657 MPN/100mls	Phoenix	Yes
			Fecal Coliform		
			546 MPN/100mls	Phoenix	Yes
			Total Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls		
		Nitrogen	Total N 2.381 mg/l	Phoenix	No
		Marogen	10(4)14 2.3011116/1	THOCHA	
		Phosphorus	Total P 0.35 mg/l	Phoenix	Yes
		Pilospilorus	Total P 0.33 mg/1	FIIOEIIIX	163
	7				
0-122	02/06/20	Bacteria	E Coli		
Mill River			161 MPN/100mls	Phoenix	No
			100 MPN/100mls	ECL	No
			Enterococci		
			272 MPN/100mls	Phoenix	No
			520 MPN/2100mls	ECL	Yes
			320 1411 14/210011113	202	163
			Fecal Coliform		
			110 MPN/100mls	Phoenix	No
			<100 MPN/100mls	ECL	No
			Total Coliform		
			6,870 MPN/100mls	Phoenix	Yes
			3,990 MPN/100mls	ECL	Yes
		Nitrogen	Total N 1.60 mg/l	Phoenix	No
			J.		
		Phosphorus	Total P 0.121 mg/l	Phoenix	No
0-124	02/06/20	Bacteria	E Coli		
0-124	02/00/20	Dacteria	L COII		L

Mill River			408 MPN/100mls	Phoenix	No
WIIII KIVEI			520MPN/100mls	ECL	Yes
			Enterococci		
			1,210 MPN/100mls	Phoenix	Yes
			960 MPN/100mls	ECL	Yes
			Fecal Coliform		
			594 MPN/100mls	Phoenix	Yes
			100 MPN/100mls	ECL	No
			Total Coliform		
			19,900	Phoenix	Yes
			MPN/100mls 20,460	ECL	Yes
			MPN/100mls		
		Nitrogen	Total N 7.77 mg/l	Phoenix	Yes
		Phosphorus	Total P 0.90 mg/l	Phoenix	Yes
0-161	03/13/20	Bacteria	E Coli		
New			2,500 MPN/100mls	Phoenix	Yes
Haven Harbor			13,140 MPN/100mls	ECL	Yes
Tiarbot			Enterococci		
			1,960 MPN/100mls	Phoenix	Yes
			2,310 MPN/100mls	ECL	Yes
			Fecal Coliform		
			1,350 MPN/100mls	Phoenix	Yes
			860 MPN/100mls	ECL	Yes
			Total Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls 57,940	ECL	Yes
			MPN/100mls	202	103
		Nitrogen	Total N 3.40 mg/l	Phoenix	Yes
		Phosphorus	Total P 0.041 mg/l	Phoenix	No
0-162	03/13/20	Bacteria	E Coli		
New			74 MPN/100mls	Phoenix	No
Haven Harbor			300 MPN/100mls	ECL	No
			Enterococci		
			657 MPN/100mls	Phoenix	Yes
			750 MPN/100mls	ECL	Yes
			Fecal Coliform		
			31 MPN/100mls	Phoenix	No
			<100 MPN/100mls	ECL	No
			Total California		
			Total Coliform		

			8,160 MPN/100mls 3,360 MPN/100mls	Phoenix ECL	Yes Yes
		Nitrogen	Total N 1.06 mg/l	Phoenix	No
		Phosphorus	Total P 0.168 mg/l	Phoenix	No
	20 110 100				
-162A	03/13/20	Bacteria	E Coli	91	
ew			727 MPN/100mls	Phoenix	Yes
aven			860 MPN/100mls	ECL	Yes
arbor			Contagnosia:		
			Enterococci	Phoenix	Yes
			594 MPN/100mls		
			11,090 MPN/100mls	ECL	Yes
			Fecal Coliform		
			350 MPN/100mls	Phoenix	Yes
			200 MPN/100mls	ECL	No
			200 MPN/10011115	ECL	NO
			Total Coliform		
			11,200 MPN/100mls	Phoenix	Yes
			14,210 NPM/100mls	ECL	Yes
			14,210 141 14, 1001113	202	
		Nitrogen	Total N 1.18 mg/l	Phoenix	No
			a M		
		Phosphorus	Total P 0.067 mg/l	Phoenix	No
				4	
)-44	03/19/20	Bacteria	E Coli		.,
Vest River			1,940 MPN/100mls	Phoenix	Yes
		20	1,610 MPN/100mls	ECL	Yes

O-44 West River	03/19/20	Bacteria	E Coli 1,940 MPN/100mls 1,610 MPN/100mls Enterococci 776 MPN/100mls 620 MPN/100mls Fecal Coliform 122 MPN/100mls 410 MPN/100mls	Phoenix ECL Phoenix ECL Phoenix ECL	Yes Yes Yes No Yes
		Nitrogen Phosphorus	Total Coliform 4,350 MPN/100mls 6,630 MPN/100mls Total N 1.02 mg/l Total P 0.163mg/l	Phoenix ECL Phoenix	Yes Yes No
O-6 West River	03/19/20	Bacteria	E Coli <10MPN/100mls 100 MPN/100mls Enterococci	Phoenix ECL	No No

			487 MPN/100mls	Phoenix	No
			1,310 MPN/100mls	ECL	Yes
			Fecal Coliform		
			<10MPN/100mls	Phoenix	No
			<100 MPN/100mls	ECS	No
			1200 1011 11/ 10011113	203	110
			Total Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls		
			23,100 MPN/100mls	ECL	Yes
		Allaurana	Tabel N. O. 71 //	Dhaaniy	Na
		Nitrogen	Total N 0.71 mg/l	Phoenix	No
		Phosphorus	Total P 0.155 mg/l	Phoenix	No
-24	03/19/20	Bacteria	E Coli		
/est River	-,,	1	86 MPN/100mls	Phoenix	No
			100 MPN/100mls	ECL	No
			Enterococci		
			141 MPN/100mls	Phoenix	No
			310 MPN/100mls	ECL	No
			Fecal Coliform		
			20 MPN/100mls	Phoenix	No
			100 MPN/100mls	ECL	No
			Total Coliform		
			19,900 MPN/100mls	Phoenix	Yes
			15,390 MPN/100mls	ECL	Yes
		Nitrogen	Total N 1.16 mg/l	Phoenix	No
			G.		
		Phosphorus	Total P 0.171 mg/l	Phoenix	No
D-25	03/19/20	Bacteria	E Coli		
Vest River			31 MPN/100mls	Phoenix	No
			100 MPN/100mls	ECL	No
			Enterno const		
			Enterococci	Phooniy	No
			455 MPN/100mls 1,830 MPN/100mls	Phoenix ECL	No Yes
			1,030 WEN/ 1001115	LCL	163
			Fecal Coliform		
			10 MPN/100mls	Phoenix	No
			<100 MPN/100mls	ECL	No
			Total Coliform		
			0 MPN/100mls	Phoenix	No
			9,060 MPN/100mls	ECL	Yes
			5,000 1411 147 10011113	202	
		Nitrogen	Total N 0.45 mg/l	Phoenix	No
		Phosphorus	Total P 0.099mg/l	Phoenix	No
O-141 New Haven	04/24/20		E Coli 218 MPN/100mls	Phoenix	No
Status Harrage			TEX MUNICIPALITY	PDOPDIV	INO

Harbor			200 MPN/100mls	ECL	No
			Enterococci 187 MPN/100mls	Phoenix	No
			520 MPN/100mls	ECL	Yes
			Fecal Coliform 131 MPN/100mls	Phoenix	No
			100 MPN/100mls	ECL	No
			Total Coliform		
			4,880 MPN/100mls 6,630 MPN/100mls	Phoenix ECL	Yes Yes
			0,030 WII W/ 10011113	LCL	163
			Total N 0.55 mg/l	Phoenix	No
			Total P 0.090mg/l	Phoenix	No
O-147 New Haven Harbor	04/24/20	Bacteria	E Coli >24,200 MPN/100mls	Phoenix	Yes
ria, sor			>241,960 MPN/100mls	ECL	Yes
			Enterococci >24,200 MPN/100mls	Phoenix	Yes
•			>241,960 MPN/100mls	ECL	Yes
			Fecal Coliform	Phoenix	Yes
			MPN/100mls	FC!	Voc
			>241,960 MPN/100mls	ECL	Yes
	, ,		Total Coliform >24,200	Phoenix	Yes
		Nitrogen	MPN/100mls >241,960 MPN/100mls	ECL	Yes
			Total N 14.01 mg/i	Dhaaniy	Voc
		Phosphorus		Phoenix	Yes
			Total P 1.76 mg/l	Phoenix	Yes
O-148 New Haven	04/27/20	Bacteria	E Coli 393 MPN/100mls	Phoenix	No
Harbor			1,450 MPN/100mls	ECL.	Yes
			Enterococci 880 MPN/100mls	Phoenix	Yes
			1,190 MPN/100mls	ECL	Yes
			Fecal Coliform 355 MPN/100mls	Phoenix	Yes
			310 MPN/100mls	ECL	Yes

			Total Coliform		
			19,900 MPN/100mls	Phoenix	Yes
			36,540 MPN/100mls	ECL	Yes
			Total N 1.40 mg/l	Phoenix	No
			10ta11V 1.40111g/1	PHOEIIIX	IVO
		Nitrogen	Total P 0.026 mg/l	Phoenix	No
		Phosphorus			
156	00/44/20	D. A. de	E Celi		
D-156	06/11/20	Bacteria	E Coli		
New Haven			<10 MPN/100mls	Phoenix	No
larbor			200 MPN/100mls	ECL	No
			Enterococci		
			2,050 MPN/100mls	Phoenix	Yes
			100 MPN/100mls	ECL	No
			Fecal Coliform		
			<10 MPN/100mls	Phoenix	No
			<100 MPN/100mls	ECL	No
			<100 WIF 14/ 10011113	LCL	140
			Total Coliform		
			373 MPN/100mls	Phoenix	No
			2,130 MPN/100mls	ECL	Yes
			_,		
		Alibusasas	T-4-1 N 10 45 //	Dhaaniu	Voc
		Nitrogen	Total N 19.45 mg/l	Phoenix	Yes
		Phosphorus	Total P 0.420 mg/l	Phoenix	Yes
			5.0.1		
0-15	10/02/20	Bacteria	E Coli		
Wintergreen			>24,200	Phoenix	Yes
Brook			MPN/100mls		Yes
			5,790 MPN/100mls	ECL	
			3,730 1411 117 10011113	202	
			Enterococci		
			24,200 MPN/100mls	Phoenix	Yes
			19,500 MPN/100mls		
				ECL	Yes
			Fecal Coliform		1
			>24,200		
			MPN/100mls		
			198,630	Phoenix	Yes
			MPN/100mls		
			1111 11, 20011113	ECL	Yes
			T-4-10 25	ECL	163
			Total Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls		
			>241,960	ECL	Yes
			MPN/100mls		
			IALLIA TOOLIII2		
			Total N 6.79 mg/l	Phoenix	Yes
		Nitrogen	Total P 1.09 mg/l	Phoenix	Yes
		Phosphorus			

1.0	10/02/20	Doctorio	E Coli		
-16	10/02/20	Bacteria		Dhoosin	Vac
intergreen			987 MPN/100mls	Phoenix	Yes
ook			750 MPN/100mls	ECL	Yes
			Enterococci		
			8,160 MPN/100mls	Phoenix	Yes
			3,830 MPN/100mls	ECL	Yes
			3,830 1411 14/ 10011113	CCL	163
			e louis		
			Fecal Coliform		
			2,600 MPN/100mls	Phoenix	Yes
			3,010 MPN/100mls	ECL	Yes
			Total Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls		
				ECI	Voc
			>241,960	ECL	Yes
			MPN/100mls		
		Nitrogen	Total N 2.49 mg/l	Phoenix	No
		Phosphorus	Total P 0.254 mg/l	Phoenix	No
		, nospilorus	101011 01204 1118/1		
	40 400 400		F C-1:		
)-21	10/02/20	Bacteria	E Coli		V
Vintergreen			10,500 MPN/100mls	Phoenix	Yes
rook			6,200 MPN/100mls	ECL	Yes
			Enterococci		
			6,870 MPN/100mls	Phoenix	Yes
			4,710 MPN/100mls	ECL	Yes
			4,/10 WPN/100mis	ECL	163
			Fecal Coliform		
			19,900 MPN/100mls	Phoenix	Yes
			41,060 MPN/100mls	ECL	Yes
			Total Coliform		
			>24,200	Phoenix	Yes
				THOCHIA	
			MPN/100mls	501	Vos
			>241,960	ECL	Yes
			MPN/100mls		
			Total N 1.38 mg/l	Phoenix	No
			3,		
			Total P 0.291 mg/l	Phoenix	No
			TOTAL F 0.231 Hig/I	THOCHIA	110
		Nitrogen			
		Phosphorus			
		· ·			
O-60A	10/29/20	Bacteria	E Coli		
	10/23/20	Dacteria	12,000 MPN/100mls	Phoenix	Yes
Wintergreen					
Brook			16,070 MPN/100mls	ECL	Yes
			Enterococci		
			19,900 MPN/100mls	Phoenix	Yes
				ECL	Yes
			3[] /b() MPN/ Hillimic		
			30,760 MPN/100mls	ECL	163

			19,900 MPN/100mls 13,960 MPN/100mls	Phoenix ECL	Yes Yes	
			Total Coliform >24,200MPN/100mls 51,720 MPN/100mls	Phoenix ECL	Yes Yes	
		Nitrogen	Total N 0.77 mg/l	Phoenix	No	
		Phosphorus	Total P 0.051 mg/l	Phoenix	No	
O-45 West River	10/29/20	Bacteria	E Coli 4,610 MPN/100mls 3,450 MPN/100mls	Phoenix ECL	Yes Yes	
			Enterococci >24,200 MPN/100mls 22,470 MPN/100mls	Phoenix	Yes Yes	
			Fecal Coliform 8,660 MPN/100mls 3,590 MPN/100mls	Phoenix ECL	Yes Yes	
			Total Coliform >24,200	Phoenix	Yes	
			MPN/100mls >241,960 MPN/100mls	ECL	Yes	
		Nitrogen	Total N 1.21 mg/l	Phoenix	No	
		Phosphorus	Total P 0.110 mg/l	Phoenix	No	

0-25	10/29/20	Bacteria	E Coli		
Vest			5,790 MPN/100mls	Phoenix	Yes
iver			5.730 MPN/100mls	ECL	Yes
			Enterococci		
			>24,200 MPN/100mls	Phoenix	Yes
			38,730 MPN/100mls	ECL	Yes
			Fecal Coliform		
			15,500 MPN/100mls	Phoenix	Yes
			5,730 MPN/100mls	ECL	Yes
			Total Coliform		
			>24,200 MPN/100mls	Phoenix	Yes
	1 1		>241,960	ECL	Yes
			MPN/100mls		
		Nitrogen	Total N 24.57 mg/l	Phoenix	Yes
		Phosphorus	Total P 4.40 mg/l	Phoenix	Yes

O-26 West	10/29/20	Bacteria	E Coli >24,200	Phoenix	Yes
liver			MPN/100mls 41,060 MPN/100mls	ECL	Yes
			Enterococci >24,200	Phoenix	Yes
			MPN/100mls 86,640 MPN/100mls	ECL	Yes
			Fecal Coliform	Observation	Wa-
			24,200 MPN/100mls	Phoenix	Yes
			19,350 MPN/100mls	ECL	Yes
			Total Coliform >24,200	Phoenix	Yes
			MPN/100mls		
			>241,960 MPN/100mls	ECL	Yes
		Nitrogen	Total N 0.98 mg/l	Phoenix	No
		Phosphorus	Total P 0.281 mg/l	Phoenix	No

O-61 Winter	04/15/21	Bacteria	E Coli >24,200	Phoenix	Yes
Green			MPN/100mls	THOUSEN.	
Brook			98,040 MPN/100mls	ECL	Yes
			Enterococci		
			Not analyzed	Phoenix	
			81,640 MPN/100mls	ECL	Yes
			Fecal Coliform		
			>24,200 MPN/100mls	Phoenix	Yes
			68,670 MPN/100mls	ECL	Yes
	-		Tatal California		
			Total Coliform >24,200		
			MPN/100mls	Phoenix	Yes
			241,960 MPN/100mls	ECL	Yes
		Nitrogen	Total N 4.43 mg/l	Phoenix	Yes
		Phosphorus	Total P 0.497 mg/l	Phoenix	Yes
0-62	04/15/21	Bacteria	E Coli		
Winter Green			>24,200 MPN/100mls	Phoenix	Yes
Brook			>241,960	ECL	Yes
_,			MPN/100mls		

					Enterococci				
					Not analyzed >241,960 MPN/100mls		Phoenix ECL		Yes
					Fecal Colifor >24,200 MPN/100ml: 19,350 MPN	m s	Phoenix ECL		Yes
					Total Colifor				
					>24,200 MPN/100ml >241,960	s	Phoenix ECL		Yes
					MPN/100ml				
			Nitrogen Phosphorus		Total N 53.		Phoenix Phoenix		Yes
	0/04/40				10(4)1 3.3				163
0-180 5200-00)	6/21/18	Bacteria		E. coli 616 MF	PN/100mls	Phoenix		Yes	
				Enterococci >24,200 MPN/100mls		Phoenix		Yes	
					oliform PN/100mls	Phoenia	t and the second	Yes	
				Total C >24,20 MPN/1		Phoenix		Yes	
		Nitroge	n	Total N	3.08 mg/l	Phoeni	(Yes	
		Phosph	orus	Total P	0.123 mg/l	Phoeni	•	No	
)-119	6/28/18	Bacteria	9	E.Coli		Phoeni	<	Yes	
5305-00)				Entero	MPN/100mls cocci MPN/100mls	Phoeni	(Yes	
					Fecal Coliform 4,110 MPN/100mls		Phoenix Y		
				Total C >242,0 MPN/1		Phoeni	×	Yes	
		Nitroge	en .	Total N	l 3.48 mg/l	Phoeni	x	Yes	
		Phosph	orus	Total P	0.545 mg/l	Phoeni	x	Yes	
0-11	11/13/18	Bacteri	a	E Coli					

	609 MPN/100mls	Phoenix	Yes
	200 MPN/100mls	ECL	
	Enterococci		
		Phoenix	Yes
	310 MPN/100mls	ECL	
	Fecal Coliform		
	383 MPN/100mls	Phoenix	Yes
	300 MPN/100mls	ECL	
	Total Coliform		
	17,300 MPN/100mls	Phoenix	Yes
	17,250 MPN/100mls	ECL	
Nitrogen	Total N 0.66 mg/l	Phoenix	No
Phosphorus	Total P 0.076 mg/i	Phoenix	No
		Enterococci 602 MPN/100mls 310 MPN/100mls Fecal Coliform 383 MPN/100mls 300 MPN/100mls Total Coliform 17,300 MPN/100mls 17,250 MPN/100mls Total N 0.66 mg/l	Enterococci 602 MPN/100mls Phoenix 310 MPN/100mls ECL Fecal Coliform 383 MPN/100mls Phoenix 300 MPN/100mls Phoenix 17,300 MPN/100mls ECL Total Coliform 17,300 MPN/100mls Phoenix 17,250 MPN/100mls ECL Nitrogen Total N 0.66 mg/l Phoenix

0-7	11/13/18	Bacteria	E Coli		
(5305-00)			>24,200	Phoenix	Yes
			MPN/100mls		
			241,960	ECL	Yes
			MPN/100mls		
		a.	Enterococci		
			>24,200 MPN/100mls	Phoenix	Yes
			>241,960	ECL	Yes
			MPN/100mls		
			Fecal Coliform	117 7	
			>24,200 MPN/100mls	Phoenix	Yes
			48,840 MPN/100mls	ECL	Yes
			Total Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls		
			>241,960	ECL	Yes
			MPN/100mls		
,		Nitrogen	Total N 14.69 mg/l		
		Phosphorus	Total P 1.34 mg/l	Phoenix	Yes
		Pilospilorus	10tai r 1.54 mg/i	Phoenix	Yes
				FIIOCITIX	163
0-10	12/28/18	Bacteria	E Coli		
(5305-00)			>24,200	Phoenix	Yes
			MPN/100mls >241,960	ECL	Yes
			MPN/100mls	ECL	Tes
			Enterococci		
			>24,200	Phoenix	Yes

			MPN/100mls		
			>241,960	ECL	Yes
			MPN/100mls		
			Fecal Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls		
			>241,960	ECL	Yes
			MPN/100mls		
			Total Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls	THOCHIA	163
			>241,960	ECL	Yes
				ECL	163
			MPN/100mls		
				pl	V
		Nitrogen	Total N 16.67 mg/l	Phoenix	Yes
		Phosphorus	Total P 1.76 mg/l	Phoenix	Yes
0-12	11/13/18	Bacteria	E Coli		
(5305-00)		www.tuttu	5,480 MPN/100mls	Phoenix	Yes
(3303-00)			5,040 MPN/100mls	ECL	Yes
			3,040 1411 14/ 10011113	CCC	163
			Enterococci		
			5,170 MPN/100mls	Phoenix	Yes
			6,770 MPN/100mls	ECL	Yes
			- 10.116		
			Fecal Coliform		L.
			1,860 MPN/100mls	Phoenix	Yes
			1,560 MPN/100mls	ECL	Yes
			Total Coliform		
			Total Coliform >24,200	Phoenix	Yes
				Phoenix	Yes
			>24,200 MPN/100mls	Phoenix	Yes
			>24,200 MPN/100mls 198,630		Yes
			>24,200 MPN/100mls	Phoenix	
			>24,200 MPN/100mls 198,630 MPN/100mls		
		Nitrogen	>24,200 MPN/100mls 198,630	ECL	Yes
		Nitrogen	>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l		
			>24,200 MPN/100mls 198,630 MPN/100mls	ECL Phoenix	Yes
		Nitrogen Phosphorus	>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l	ECL	Yes
	42/20/42	Phosphorus	>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l Total P 0.229 mg/l	ECL Phoenix	Yes
013	12/28/18		>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l Total P 0.229 mg/l	ECL Phoenix Phoenix	Yes No No
O13 (5305-00)	12/28/18	Phosphorus	>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l Total P 0.229 mg/l E Coli >24,200	ECL Phoenix	Yes
	12/28/18	Phosphorus	>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l Total P 0.229 mg/l E Coli >24,200 MPN/100mls	ECL Phoenix Phoenix Phoenix	Yes No No Yes
	12/28/18	Phosphorus	>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l Total P 0.229 mg/l E Coli >24,200 MPN/100mls >241,960	ECL Phoenix Phoenix	Yes No No
	12/28/18	Phosphorus	>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l Total P 0.229 mg/l E Coli >24,200 MPN/100mls	ECL Phoenix Phoenix Phoenix	Yes No No Yes
	12/28/18	Phosphorus	>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l Total P 0.229 mg/l E Coli >24,200 MPN/100mls >241,960	ECL Phoenix Phoenix Phoenix	Yes No No Yes
	12/28/18	Phosphorus	>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l Total P 0.229 mg/l E Coli >24,200 MPN/100mls >241,960	ECL Phoenix Phoenix Phoenix ECL	Yes No No Yes
	12/28/18	Phosphorus	>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l Total P 0.229 mg/l E Coli >24,200 MPN/100mls >241,960 MPN/100mls	ECL Phoenix Phoenix Phoenix	Yes No No Yes
	12/28/18	Phosphorus	>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l Total P 0.229 mg/l E Coli >24,200 MPN/100mls >241,960 MPN/100mls Enterococci >24,200	ECL Phoenix Phoenix Phoenix ECL	Yes No No Yes Yes
	12/28/18	Phosphorus	>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l Total P 0.229 mg/l E Coli >24,200 MPN/100mls >241,960 MPN/100mls Enterococci >24,200 MPN/100mls	ECL Phoenix Phoenix ECL Phoenix	Yes No No Yes Yes
	12/28/18	Phosphorus	>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l Total P 0.229 mg/l E Coli >24,200 MPN/100mls >241,960 MPN/100mls	ECL Phoenix Phoenix Phoenix	Yes No No Yes
	12/28/18	Phosphorus	>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l Total P 0.229 mg/l E Coli >24,200 MPN/100mls >241,960 MPN/100mls Enterococci >24,200 MPN/100mls	ECL Phoenix Phoenix ECL Phoenix	Yes No No Yes Yes
	12/28/18	Phosphorus	>24,200 MPN/100mls 198,630 MPN/100mls Total N 0.44 mg/l Total P 0.229 mg/l E Coli >24,200 MPN/100mls >241,960 MPN/100mls Enterococci >24,200	ECL Phoenix Phoenix Phoenix ECL	Yes No No Yes Yes

		Nitrogen	Fecal Coliform >24,200 MPN/100mls 155,310 MPN/100mls Total Coliform >24,200 MPN/100mls >241,960 MPN/100mls Total N 17.49mg/l	Phoenix ECL Phoenix ECL Phoenix	Yes Yes Yes Yes
		Phosphorus	Total P 2.02mg/l	Phoenix	Yes
O-41 (5305-00)	12/28/18	Bacteria	E Coli >24,200 MPN/100mls	Phoenix	Yes
			>241,960 MPN/100mls	ECL	Yes
			Enterococci >24,200 MPN/100mls	Phoenix	Yes
			92,080 MPN/100mls	ECL	Yes
			Fecal Coliform >24,200 MPN/100mls	Phoenix	Yes
			>241,960 MPN/100mls	ECL	Yes
			Total Coliform >24,200	Phoenix	Yes
			MPN/100mls >241,960 MPN/100mls	ECL	Yes
		Nitrogen	Total N 11.49 mg/l	Phoenix	Yes
		Phosphorus	Total P 1.33 mg/l	Phoenix	Yes
0.46	12/21/10	Ractoria	E Coli		
O-46 (5305-00)	12/21/18	Bacteria	637 MPN/100mls 410 MPN/100mls	Phoenix ECL	Yes Yes
			Enterococci 2,280 MPN/100mls	Phoenix	Yes
			1,990MPN/100mls	ECL	Yes
			Fecal Coliform 197 MPN/100mls	Phoenix	Yes

			200 MPN/100mls	ECL	Yes
			Total Coliform 9,800 MPN/100mls 8,420 MPN/100mls	Phoenix ECL	Yes Yes
		Nitrogen	Total N 0.42 mg/l	Phoenix	No
		Phosphorus	Total P 0.13 mg/l	Phoenix	No
O-47 (5305-00)	12/21/18	Bacteria	E Coli 9,140 MPN/100mls 3,360 MPN/100mls	Phoenix ECL	Yes Yes
			Enterococci 3,870 MPN/100mls 1,580 MPN/100mls	Phoenix ECL	Yes Yes
			Fecal Coliform 5,170 MPN/100mls 1,610 MPN/100mls	Phoenix ECL	Yes Yes
			Total Coliform 10,100 MPN/100mls 13,540 MPN/100mls	Phoenix ECL	Yes Yes
		Nitrogen	Total N 0.72 mg/l	Phoenix	No
		Phosphorus	Total P 0.161 mg/l	Phoenix	No
0-57	12/28/18	Bacteria	E Coli		
(5305-00)	12,20,10	bucceriu	>24,200 MPN/100mls	Phoenix	Yes
			>241,960 MPN/100mls	ECL	Yes
			Enterococci >24,200 MPN/100mls	Phoenix	Yes
			>241,960 MPN/100mls	ECL	Yes
			Fecal Coliform >24,200 MPN/100mls	Phoenix	Yes
			>241,960 MPN/100mls	ECL	Yes
			Total Coliform >24,200 MPN/100mls	Phoenix	Yes
			>241,960 MPN/100mls	ECL	Yes
		Nitrogen	Total N 32.24 mg/l	Phoenix	Yes
		Phosphorus	Total P 4.09 mg/l	Phoenix	Yes

-58 305-00)	12/28/18	Bacteria	E Coli >24,200	Phoenix	Yes
303 001			MPN/100mls		
			>241,960	ECL	Yes
			MPN/100mls		
			Enterococci		
			>24,200	Phoenix	Yes
			MPN/100mls		
			81,640	ECL	Yes
			MPN/100mls		
			A Company		
			Fecal Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls	501	
			>241,960	ECL	Yes
			MPN/100mls		
			Total Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls		
			>241,960	ECL	Yes
			MPN/100mls		
		Nitrogen	Total N 26.01 mg/l	Phoenix	Yes
		Phosphorus	Total P 2.96 mg/l	Phoenix	Yes

		E Coli		
		3,080 MPN/100mls	Phoenix	Yes
		2,350 MPN/100mls	ECL	Yes
				Yes
		1,350 MPN/100mls	ECL	Yes
				Yes
		1,610 MPN/100mls	ECL	Yes
			Phoenix	Yes
			ECL	Yes
		MPN/100mls		
	Nitrogen	Total N 0.49 mg/l	Phoenix	No
	Phosphorus	Total P 0.182 mg/l	Phoenix	No
12/28/18	Bacteria	E Coli		
		30 MPN/100mls	Phoenix	No
		100 MPN/100mls	ECL	No
		Entoropool		
	12/28/18	Phosphorus	Enterococci 2,190 MPN/100mls 1,350 MPN/100mls 1,350 MPN/100mls Fecal Coliform 1,480 MPN/100mls 1,610 MPN/100mls Total Coliform >24,200 MPN/100mls 61,310 MPN/100mls 61,310 Total N 0.49 mg/l Phosphorus Total P 0.182 mg/l 12/28/18 Bacteria E Coli 30 MPN/100mls	Enterococci 2,190 MPN/100mls 1,350 MPN/100mls 1,350 MPN/100mls 1,480 MPN/100mls 1,610 MPN/100mls 1,610 MPN/100mls ECL Total Coliform >24,200 MPN/100mls 61,310 MPN/100mls 61,310 MPN/100mls FCL Nitrogen Total N 0.49 mg/l Phoenix Phoenix Phoenix ECL Phoenix ECL Phoenix ECL Phoenix ECL Phoenix ECL Phoenix ECL Phoenix ECL Phoenix ECL Phoenix ECL Phoenix ECL Phoenix ECL

			249 MPN/100mls 8,600 MPN/100mls	Phoenix ECL	No Yes
			Fecal Coliform		
			20 MPN/100mls 100 MPN/100mls	Phoenix ECL	No No
			Total Coliform 13,000 MPN/100mls	Phoenix	Yes
			5,810 MPN/100mls	ECL	Yes
		Nitrogen	Total N 0.95 mg/l	Phoenix	No
		Phosphorus	Total P 0.07 mg/l	Phoenix	No
0-81	6/18/19	Bacteria	E Coli		
(5305-00)	0,10,13	Bucconu	2,060 MPN/100mls	Phoenix	Yes
			Enterococci 9,210 MPN/100mls	Phoenix	Yes
			Fecal Coliform 934 MPN/100mls	Phoenix	Yes
			Total Coliform >24,200 MPN/100mls	Phoenix	Yes
		Nitrogen	Total N 0.76 mg/l	Phoenix	No
		Phosphorus	Total P 0.072 mg/l	Phoenix	No
O-87 (5305-00)	12/28/18	Bacteria	E Coli 30 MPN/100mls 100 MPN/100mls	Phoenix ECL	No No
			Enterococci 249 MPN/100mls 8,600 MPN/100mls	Phoenix ECL	No Yes
			Fecal Coliform 20 MPN/100mls 100 MPN/100mls	Phoenix ECL	No No
			Total Coliform 13,000	Phoenix	Yes
			MPN/100mls 5,810 MPN/100mls	ECL	Yes
		Nitrogen	Total N 24.37 mg/l	Phoenix	No
		Phosphorus	Total P 0.07 mg/l	Phoenix	No

00	12/20/10	Pactoria	E Coli		
0-88	12/28/18	Bacteria		Dhooniy	Vos
5305-00)			591 MPN/100mls	Phoenix	Yes
			520 MPN/100mls	ECL	Yes
			Enterococci		
			471 MPN/100mls	Phoenix	Yes
			1,100 MPN/100mls	ECL	Yes
			2,200 1111 11, 20011113	1	
			Facal California		
			Fecal Coliform	-1	
			637 MPN/100mls	Phoenix	Yes
			200 MPN/100mls	ECL	Yes
			Total Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls		
				r.c.	Vac
			30,760	ECL	Yes
			MPN/100mls		
		Nitrogen	Total N 0.826 mg/l	Phoenix	Yes
		Phosphorus	Total P 0.105 mg/l	Phoenix	No
D-89	12/21/18	Bacteria	E Coli		
	75/ 51/ 10	Dacteria	7,700 MPN/100mls	Phoenix	Yes
5305-00)					
	17.		9,590 MPN/100mls	ECL	Yes
			Enterococci		
			5,480 MPN/100mls	Phoenix	Yes
			5,540 MPN/100mls	ECL	Yes
			0,0 10 1111 11, 20011110		
			Fecal Coliform		
				Dhaanin	Vos
			2,610 MPN/100mls	Phoenix	Yes
			2,980 MPN/100mls	ECL	Yes
			Total Coliform		
			>24,200	Phoenix	Yes
			MPN/100mls	· Hoelin	
				F.C1	Vee
			46,110	ECL	Yes
			MPN/100mls		
		Nitrogen	Total N 0.72 mg/l	Phoenix	No
		Phosphorus	Total P 0.133 mg/l	Phoenix	No
		1 1105pilot us			
	40/04/45		E C-II		
	12/21/18	Bacteria	E Coli		
			>24,200	Phoenix	Yes
			A 4DAL /4 00 l-		
			MPN/100mls		
			MPN/100mis		
O-121 (5302-00)					
			Enterococci	Phooniv	Vec
			Enterococci >24,200	Phoenix	Yes
			Enterococci	Phoenix	Yes
			Enterococci >24,200 MPN/100mls	Phoenix	Yes
			Enterococci >24,200	Phoenix Phoenix	Yes

			MPN/100mls		
			Total Coliform >24,200 MPN/100mls	Phoenix	Yes
		Nitrogen	Total N 26.94 mg/l	Phoenix	Yes
		Phosphorus	Total P 4.0 mg/l	Phoenix	Yes
0-122 (5302-00)	4/26/19	Bacteria	E Coli 7,270 MPN/100mls	Phoenix	Yes
			Enterococci 3,080 MPN/100mls	Phoenix	Yes
			Fecal Coliform 4,880 MPN/100mls	Phoenix	Yes
			Total Coliform		
			>24,200 MPN/100mls	Phoenix	Yes
		Nitrogen	Total N 3.77 mg/l	Phoenix	Yes
		Phosphorus	Total P 0.40 mg/l	Phoenix	Yes
O-124 (5302-00)	4/26/19	Bacteria	E Coli >24,200 MPN/100mls	Phoenix	Yes
			Enterococci 4,610 MPN/100mls	Phoenix	Yes
			Fecal Coliform >24,200 MPN/100mls	Phoenix	Yes
			Total Coliform >24,200 MPN/100mls	Phoenix	Yes
		Nitrogen	Total N 78.95 mg/l	Phoenix	Yes
		Phosphorus	Total P 8.51 mg/l	Phoenix	Yes
O-124X (5302-00)	4/26/19	Bacteria	E Coli 216 MPN/100mls	Phoenix	No
			Enterococci 134 MPN/100mls	Phoenix	No
			Fecal Coliform 395 MPN/100mls	Phoenix	Yes

			Total Coliform 19,900 MPN/100mls	Phoenix	Yes
		Nitrogen	Total N 2.623 mg/l	Phoenix	Yes
		Phosphorus	Total P 0.196 mg/l	Phoenix	no
O-125 (5302-00)	4/26/19	Bacteria	E Coli 10 MPN/100mls	Phoenix	No
			Enterococci 61 MPN/100mls	Phoenix	no
			Fecal Coliform 10 MPN/100mls	Phoenix	Yes
			Total Coliform 934 MPN/100mls	Phoenix	Yes
		Nitrogen	Total N 1.13 mg/l	Phoenix	Yes
		Phosphorus	Total P 0.067 mg/l	Phoenix	Yes
O-126 (5302-00)	4/26/19		E Coli >24,200 MPN/100mls	Phoenix	Yes
			Enterococci >24,200 MPN/100mls	Phoenix	Yes
			Fecal Coliform >24,200 MPN/100mls	Phoenix	Yes
			Total Coliform >24,200 MPN/100mls	Phoenix	Yes
			Total N 26.94 mg/l	Phoenix	Yes
			Total P 4.00 mg/l	Phoenix	Yes
O-126 (5302-00)	12/9/19	Bacteria	E Coli 2,600 MPN/100mls 2,750 MPN/100mls	Phoenix ECL	Yes Yes
			Enterococci >24,200 MPN/100mls 111,990	Phoenix ECL	Yes
			MPN/100mls		
			Fecal Coliform 1,080 MPN/100mls 2,130 MPN/100mls	Phoenix ECL	Yes Yes

			Total Coliform >24,200 MPN/100mls	Phoenix	Yes	
			>241,960 MPN/100mls	ECL	Yes	
		Nitrogen	Total N 4.014 mg/l	Phoenix	Yes	
		Phosphorus	Total P 0.812 mg/l	Phoenix	Yes	
0-127	4/26/19	Bacteria	E Coli 703 MPN/100mls	Phoenix	Yes	
			Enterococci 1,170 MPN/100mls	Phoenix	Yes	
			Fecal Coliform 24,200 MPN/100mls	Phoenix	No	
			Total Coliform >24,200 MPN/100mls	Phoenix	Yes	
		Nitrogen	Total N 2.445 mg/l	Phoenix	No	
		Phosphorus	Total P 0.114 mg/l	Phoenix	No	
O-128 (5302-00)	4/26/19	Bacteria	E Coli 218 MPN/100mls	Phoenix	No	
			Enterococci 1070 MPN/100mls	Phoenix	Yes	
			Fecal Coliform 98 MPN/100mls	Phoenix	No	
			Total Coliform >24,200 MPN/100mls	Phoenix	Yes	
		Nitrogen	Total N 0.971 mg/l	Phoenix	No	
		Phosphorus	Total P 0.248 mg/l	Phoenix	No	

Due to the size of this document computer glitches have occurred in preparing it. For 2022 water testing results please refer to Appendix 1. It is hoped this problem can be resolved before the final report is published in April 2023.

2.2 Credit for screening data collected under 2004 permit

If any outfalls to impaired waters were sampled under the 2004 MS4 permit, that data can count towards the monitoring requirements under the modified 2017 MS4 permit. Complete the table below to record sampling data for any outfalls to impaired waters under the 2004 MS4 permit.

Outfall	Sample date	Parameter (Nitrogen, Phosphorus, Bacteria, or Other pollutant of concern)	Results	Name of Laboratory (if used)	Follow-up required?
O-70 (5305-00)	Various dates between 2005 and 2016.	Bacteria E-coli 15 samples in total	Best 60 Worst 25,994 Average 6,336 (MPN/100mls)	Various Labs	Yes
		Total Nitrogen 13 samples in total	Best 1.22 Worst 5.36 Average 2.46 (mg/l)		
		Total Phosphorus 13 samples in total	Best 0 Worst 0.42 Average 0.19 (mg/l)		
O-109 (5000-48)	Various dates between 2005 and 2016.	Bacteria E-coli 14 samples in total	Best 228 Worst 30,100 Average 4,815 (MPN/100mls)	Various Labs	Yes
		Total Nitrogen 13 samples in total	Best 1.66 Worst 6.25 Average 3.09 (mg/l)		
		Total Phosphorus 13 samples in total Nitrogen	Best 0 Worst 0.90 Average 0.44 (mg/l)		
O-147 (5000-48)	Various dates between 2005 and 2016.	Bacteria E-coli 15 samples in total	Best 4 Worst 29,700 Average 5,100 (MPN/100mls)	Various Labs	Yes
		Total Nitrogen 13 samples in total	Best 0.16 Worst 6.13 Average 3.12 (mg/l)		
		Total Phosphorus 13 samples in total Nitrogen	Best 0 Worst 3.6 Average 0.54 (mg/l)		
O-156 (5200-00)	Various dates between 2005 and 2016	Bacteria E-coli 15 samples in total	Best 10 Worst >24,200 Average 3,051 (MPN/100mls)	Various Labs	Yes

		Total Nitrogen 13 samples in total	Best 0.0 Worst 26.45 Average 4.30 (mg/l)		
		Total Phosphorus 13 samples in total Nitrogen	Best 0.08 Worst 1.70 Average 0.72 (mg/l)		
O-249 (5200-00)	Various dates between 2005 and 2016	Bacteria E-coli 15 samples in total	Best 90 Worst 36,100 Average 4,497 (MPN/100mls)	Various Labs	Yes
		Total Nitrogen 13 samples in total	Best 0.22 Worst 4.47 Average 2.30 (mg/l)		
		Total Phosphorus 13 samples in total Nitrogen	Best 0.11 Worst 2.57 Average 0.59 (mg/l)		
0-253 (5200-00)	Various dates between 2005 and 2016	Bacteria E-coli 15 samples in total	Best 10 Worst >24,200 Average 5,888 (MPN/100mls)	Various Labs	Yes
		Total Nitrogen 13 samples in total	Best 0.19 Worst 4.47 Average 3.04 (mg/l)		
		Total Phosphorus 13 samples in total Nitrogen	Best 0.0 Worst 0.66 Average 0.30 (mg/l)		

3. Follow-up investigations (Section 6(i)(1)(D) / page 43)

Provide the following information for outfalls exceeding the pollutant threshold.

Outfall	Status of drainage area investigation	Control measure implementation to address impairment
O-180 (5200-00)	Dry weather testing was attempted, but there was no flow in the network. It was subsequently CCTVed throughout, and no illicit connections were detected. Finally, stormwater flowing into some of its catch basins was tested during the same storm event as the outfall. Pollutant levels at the catch basins were of the same order of magnitude as those at the outfall.	No control measures have been implemented, as the high pollutant levels are believed to be caused by wildlife in the area.

4. Prioritized outfall monitoring (Section 6(i)(1)(D) / page 43)

Once outfall screening has been completed for at least 50% of outfalls to impaired waters, identify 6 of the highest contributors of any pollutants of concern. Begin monitoring these outfalls on an annual basis by July 1, 2020.

Laboratory (if used)

Data is now available for 50% of the outfalls, and annual monitoring will begin during 2022.

Part III: Additional IDDE Program Data [This section required beginning with 2018 Annual Report]

1. Assessment and Priority Ranking of Catchments data (Appendix B (A)(7)(c) / page 5)

Provide a list of all catchments with ranking results (DEEP basins may be used instead of manual catchment delineations).

1. Catchment ID (DEEP Basin ID)	2. Category	3. Rank
5302-00 Mill River	Problem	1
5305-00 West River	Problem	2
5304-00 Wintergreen Brook	Problem	3
5000-48 South Central Shoreline (Inner Harbor)	Problem	4
5200-00 Quinnipiac	High Priority	5
5000-45 South Central Shoreline (Morris Cove)	Low Priority	6

2. Outfall and Interconnection Screening and Sampling data (Appendix B (A)(7)(d) / page 7)

2.1 Dry weather screening and sampling data from outfalls and interconnections

Provide sample data for outfalls where flow is observed. Only include Pollutant of concern data for outfalls that discharge into stormwater impaired waterbodies.

Interconnection /s	creening sample Ammon	a Chlorine	Conductivity	Salinity	E. coli or enterococcus	Surfactants	Water Temp	Pollutant of concern	If required, follow-up actions taken
--------------------	-----------------------	------------	--------------	----------	-------------------------	-------------	---------------	----------------------	--------------------------------------

No. decoupables				
No dry weather				
screening has				
been				
undertaken to				
date				

2.2 Wet weather sample and inspection data

Provide sample data for outfalls and key junction manholes of any catchment area with at least one System Vulnerability Factor.

Outfall / Interconnection ID	Sample date	Ammonia Mg/l	Chlorine Mg/l	Conductivity Umhos/cm	Salinity ppt	E. coli or Enterococcus MPN/100mls	Surfactants Mg/I	Water Temp	Pollutant of concern
D-180	6/21/18	0.08	<0.02	678	<0.5	See above	<0.05	Not recorded	Bacteria N P
0-119	6/28/18	0.42	< 0.02	112	<0.5	See above	0.67	Not recorded	Bacteria N P
0-11	11/13/18	0.17	< 0.02	186	<0.5	See above	0.09	10.2	Bacteria N P
0-7	11/13/18	5.14	<0.02	505	<0.5	See above	0.86	16	Bacteria N P
O-10	12/28/18	3.64	< 0.02	678	<0.5	See above	0.25	12.2	Bacteria N P
O-12	11/13/18	< 0.05	< 0.02	106	<0.5	See above	<0.05	9.8	Bacteria N P
O-13	12/28/18	4.60	< 0.02	276	<0.5	See above	0.35	11.5	Bacteria N P
0-14	11/13/18	< 0.05	< 0.02	118	<0.5	See above	0.07	9.5	Bacteria N P
0-41	12/28/18	3.42	<0.02	276	<0.5	See above	0.75	8.2	Bacteria N P
0-46	12/21/18	0.06	<0.02	14	<0.5	See above	< 0.05	9.5	Bacteria N P
0-47	12/21/18	0.10	< 0.02	15	<0.5	See above	0.11	8.4	Bacteria N P
O-57	12/28/18	13.10	<0.02	488	<0.5	See above	2.15	17.6	Bacteria N P
O-58	12/28/18	11.50	< 0.02	515	<0.5	See above	2.23	11.9	Bacteria N P
O-66	11/13/18	0.15	0.02	24	< 0.5	See above	< 0.05	8.8	Bacteria N P
O-68	12/28/18	0.40	< 0.02	120	<0.5	See above	0.12	5.3	Bacteria N P
O-87	12/28/18	10.8	< 0.02	528	<0.5	See above	6.29	13.4	Bacteria N P
O-88	12/28/18	0.22	< 0.02	51	<0.5	See above	0.14	7.5	Bacteria N P
O-89	12/21/18	0.14	< 0.02	39	<0.5	See above	0.11	10.7	Bacteria N P
0-121	12/21/18	0.10	< 0.02	49	<0.5	See above	0.08	10.6	Bacteria N P
0-132	12/21/18	0.23	< 0.02	300	< 0.5	See above	0.07	12.1	Bacteria N P
O-138	12/21/18	0.14	0.03	48	<0.5	See above	<0.05	10.3	Bacteria N P
0-81	6/18/19	0.13	<0.02	42	<0.5	See above	<0.05	21.4	Bacteria N P
0-122	4/26/19	0.37	< 0.02	179	<0.5	See above	0.16	12.6	Bacteria N P
0-124	4/26/19	34.20	<0.02	471	<0.5	See above	13.9	14.4	Bacteria N P
O-124X	4/26/19	0.92	<0.02	432	<0.5	See above	0.44	13.7	Bacteria N P

D-125	4/26/19	0.17	< 0.02	4250	3.1	See above	< 0.05	11.7	Bacteria N P
D-126	4/26/19	14.5	< 0.02	608	< 0.5	See above	1.92	13.2	Bacteria N P
0-126	12/9/19	0.51	< 0.02	205	<0.5	See above	0.2	9.9	Bacteria N P
0-127	4/26/19	0.18	< 0.02	254	<0.5	See above	0.09	13.3	Bacteria N P
0-128	4/26/19	0.11	< 0.02	578	< 0.5	See above	0.13	13.6	Bacteria N P
)-128	12/9/19	**	**	**	**	See above	**	**	Bacteria N P
)-129	6/18/19	0.12	< 0.02	19	<0.5	See above	< 0.05	21.3	Bacteria N P
)-129	12/9/19	0.44	< 0.02	928	0.5	See above	0.41	9.0	Bacteria N P
0-133	6/18/19	<0.25	<0.02	525	<0.5	See above	0.07	22.1	Bacteria N P
0-133	6/18/19	<0.25	<0.02	60	<0.5	See above	0.21	22	Bacteria N P
7-134	0/10/13	10.23	10.02						
)-122	2/6/20	0.36	<0.02	277	<0.5	See above	0.11	3.4	Bacteria N P
D-124	2/6/20	1.06	<0.10	902	<0.05	See above	0.21	4.3	Bacteria N P
0-124	3/13/20	0.13	<0.02	487	<0.5	See above	< 0.05	9.0	Bacteria N P
)-162	3/13/20	0.3	<0.02	30	<0.5	See above	0.27	9.8	Bacteria N P
)-162A	3/13/20	0.17	<0.02	25	<0.5	See above	0.06	9.6	Bacteria N P
)-44	3/19/20	0.29	0.03	29	<0.5	See above	0.19	7.4	Bacteria N P
)-6	3/19/20	0.06	<0.02	15	<0.5	See above	0.08	6.3	Bacteria N P
)-24	3/19/20	0.13	<0.02	9	<0.5	See above	0.06	6.1	Bacteria N P
)-25	3/19/20	0.10	<0.02	21	<0.5	See above	< 0.05	6.0	Bacteria N P
)-141	4/24/20	0.13	<0.02	390	<0.5	See above	0.18	6.6	Bacteria N P
)-147	4/24/20	7.13	<0.02	933	0.5	See above	1.04	11.2	Bacteria N P
)-148	4/27/20	<0.05	<0.02	403	<0.5	See above	0.07	9.8	Bacteria N P
)-156	6/11/20	2.67	<0.02	238,000	328	See above	0.68	21.0	Bacteria N P
)-15	10/2/20	0.5	0.12	182	<0.5	See above	0.25	20.3	Bacteria N P
)-16	10/2/20	0.16	<0.02	206	<0.5	See above	0.19	18.7	Bacteria N P
)-21	10/2/20	0.16	<0.02	161	<0.5	See above	161	19.8	Bacteria N P
)-60A	10/29/20	0.21	<0.02	15	<0.5	See above	0.25	12.2	Bacteria N P
)-45	10/29/20	0.33	<0.02	29	<0.5	See above	0.16	12.0	Bacteria N P
)-25	10/29/20	1.35	0.04	77	<0.5	See above	0.34	10.8	Bacteria N P
0-26	10/29/20	0.15	<0.02	35	<0.5	See above	0.14	11.9	Bacteria N P
0-61	04/15/21	2.54	<0.02	216	<0.5	See above	0.46	12.2	Bacteria N P
	04/15/21	21.4	<0.02	565	<0.5	See above	11.4	17.2	Bacteria N P

Due to the size of this document computer glitches have occurred in preparing it. For 2022 water testing results please refer to Appendix 1. It is hoped this problem can be resolved before the final report is published in April 2023.

3. Catchment Investigation data (Appendix B (A)(7)(e) / page 9)

3.1 System Vulnerability Factor Summary

For those catchments being investigated for illicit discharges (i.e. categorized as high priority, low priority, or problem) document the presence or absence of System Vulnerability Factors (SVF). If present, report which SVF's were identified. An example is provided below.

Outfall ID	Receiving Water		System Vulnerability Factors
O-180	5200-00 Quinnipiac	9, 10	
0-119	5305-00 West River	6, 9, 10	
0-11	5305-00 West River	5, 6, 10	
0-7	5305-00 West River	6, 10	
0-10	5305-00 West River	5, 6, 10	
0-12	5305-00 West River	5, 6, 10	
O-13	5305-00 West River	5, 6, 10	
0-14	5305-00 West River	6, 10	
0-41	5305-00 West River	6, 10	
O-46	5305-00 West River	6, 10	
0-47	5305-00 West River	6, 10	
O-57	5305-00 West River	6	
O-58	5305-00 West River	6	
0-66	5305-00 West River	6, 10	
O-68	5305-00 West River	10	
0-81	5305-00 West River	6	
O-87	5305-00 West River	6, 9, 10	
O-88	5305-00 West River	6, 9, 10	
O-89	5305-00 West River	6, 9, 10	
O-121	5302-00 Mill River	6, 9, 10	
0-122	5302-00 Mill River	6, 9, 10	
0-124	5302-00 Mill River	6, 9, 10	
O-124X	5302-00 Mill River	6, 9, 10	

	EDGG GG AAIH Dissan	6.0.10
0-125	5302-00 Mill River	6, 9, 10
0-126	5302-00 Mill River	6, 9, 10
0-127	5302-00 Mill River	6, 9, 10
0-128	5302-00 Mill River	6, 9, 10
0-129	5302-00 Mill River	6, 9, 10
0-132	5302-00 Mill River	6, 9, 10
0-133	5302-00 Mill River	6, 9, 10
0-134	5302-00 Mill River	6, 9, 10
O-138	5302-00 Mill River	6, 9, 10
0-122	5302-00 Mill River	6 ,9, 10
0-124	5302-00 Mill River	6 ,9, 10
0-161	5000-48 Inner Harbor	6 ,9, 10
0-162	5000-48 Inner Harbor	6 ,9, 10
O-162A	5000-48 Inner Harbor	6, 9, 10
O-6	5305-00 West River	6, 9, 10
0-24	5305-00 West River	6, 9, 10
O-25	5305-00 West River	6, 9, 10
0-141	5000-48 Inner Harbor	6, 9, 10
0-147	5000-48 Inner Harbor	6, 9, 10
0-148	5000-48 Inner Harbor	6, 9, 10
0-156	5000-48 Inner Harbor	6, 9, 10
0-15	5304-00 Wintergreen Brook	6, 9, 10
0-16	5304-00 Wintergreen Brook	6, 9, 10
0-21	5304-00 Wintergreen Brook	6, 9, 10
O-60A	5304-00 Wintergreen Brook	6, 9, 10
0-45	5305-00 West River	6, 9, 10
0-25	5305-00 West River	6, 9, 10
0-26	5305-00 West River	6, 9, 10
0-44	5305-00 West River	6, 9, 10
0-61	5304-00 Wintergreen Brook	6, 9, 10
0-62	5304-00 Wintergreen brook	6, 9, 10
0-109	5000-48 Inner Harbor	6, 9, 10
0-76	5305-00 West River	6, 9, 10
0-85	5305-00 West River	6, 9, 10
0-90	5305-00 West River	6, 9, 10
0-115	5000-48 Inner Harbor	6,9,10
0-114	5000-48 Inner Harbor	6,9,10
0-113	5000-48 Inner Harbor	6,9,10
0-113	5000-48 Inner Harbor	6,9,10
0-111	JOOU TO IIIICI TIGI DOI	- ,-,

O-103	5000-48 Inner Harbor	6, 9, 10	
O-105	5000-48 Inner Harbor	6, 9, 10	
0-106	5000-48 Inner Harbor	6, 9, 10	
O-107	5000-48 Inner Harbor	6, 9, 10	
O-100	5000-48 Inner Harbor	6, 9, 10	
0-102	5000-48 Inner Harbor	6, 9, 10	
0-153	5000-48 Inner Harbor	6, 9, 10	
0-164	5000-48 Inner Harbor	6	
0-163	5000-48 Inner Harbor	6	
0-70	5305-00 West River	6, 9, 10	
0-77	5000-48 Inner Harbor	6, 9, 10	
O-79	5304-05 Beaver Pond	6, 9, 10	
0-78	5304-05 Beaver Pond	6, 9, 10	
0-149	5000-48 Inner Harbor	6	
O-150	5000-48 Inner Harbor	6	
0-151	5000-48 Inner Harbor	6	
0-152	5000-48 Inner Harbor	6	

Where SVFs are:

- 1. History of SSOs, including, but not limited to, those resulting from wet weather, high water table, or fat/oil/grease blockages.
- 2. Sewer pump/lift stations, siphons, or known sanitary sewer restrictions where power/equipment failures or blockages could readily result in SSOs.
- 3. Inadequate sanitary sewer level of service (LOS) resulting in regular surcharging, customer back-ups, or frequent customer complaints.
- 4. Common or twin-invert manholes serving storm and sanitary sewer alignments.
- 5. Common trench construction serving both storm and sanitary sewer alignments.
- 6. Crossings of storm and sanitary sewer alignments.
- 7. Sanitary sewer alignments known or suspected to have been constructed with an underdrain system;
- 8. Sanitary sewer infrastructure defects such as leaking service laterals, cracked, broken, or offset sanitary infrastructure, directly piped connections between storm drain and sanitary sewer infrastructure, or other vulnerability factors identified through Inflow/Infiltration Analyses, Sanitary Sewer Evaluation Surveys, or other infrastructure investigations.
- 9. Areas formerly served by combined sewer systems.
- 10. Any sanitary sewer and storm drain infrastructure greater than 40 years old in medium and densely developed areas.
- 11. Widespread code-required septic system upgrades required at property transfers (indicative of inadequate soils, water table separation, or other physical constraints of the area rather that poor owner maintenance).
- 12. History of multiple local health department or sanitarian actions addressing widespread septic system failures (indicative of inadequate soils, water table separation, or other physical constraints of the area rather that poor owner maintenance).

3.2 Key junction manhole dry weather screening and sampling data

Key Junction Manhole ID	Screening / Sample date	Visual/ olfactory evidence of illicit discharge	Ammonia	Chlorine	Surfactants
No dry weather samples were taken during 2022					

3.3 Wet weather investigation outfall sampling data

Outfall ID	Sample date	Ammonia	Chlorine	Surfactants
See 4.2.2				
above.				

3.4 Data for each illicit discharge source confirmed through the catchment investigation procedure

Discharge location	Source location	Discharge description	Method of discovery	Date of discovery	Date of elimination	Mitigation or enforcement action	Estimated volume of flow removed
No illicit discharge locations were found in CCTV footage reviewed during 2022							

Part IV: Certification

"I have personally examined and am familiar with the information submitted in this document and all attachments thereto, and I certify that, based on reasonable investigation, including my inquiry of those individuals responsible for obtaining the information, the submitted information is true, accurate and complete to the best of my knowledge and belief. I understand that a false statement made in this document or its attachments may be punishable as a criminal offense, in accordance with Section 22a-6 of the Connecticut General Statutes, pursuant to Section 53a-157b of the Connecticut General Statutes, and in accordance with any other applicable statute."

Chief Elected Official or Principal Executive Officer	Document Prepared by
Print name: Mayor Justin Elicker	Print name: Giovanni Zinn, PE – City Engineer
Signature / Date:	Signature / Date: